

* =mandatory field)

- **Investigator:***
 - **Name*:** Dr. Christopher Sabine
 - **Organization:** NOAA/PMEL
 - **Address:**
NOAA/PMEL
7600 Sand Point Way NE
Seattle Washington, 98115 USA
Phone: 206-526-4809
 - **Email:** chris.sabine@noaa.gov
 - **Dataset Info:***
 - Dataset_ID*: [Papa_145W_50N_Jun2009_Mar2010](#)
 - **Submission Dates:***
 - Initial_Submission: [20111004](#) (YYYYMMDD)
 - Revised_Submission: (YYYYMMDD)
 - **Cruise Info:***
 - **Experiment:**
 - Experiment_Name*:
 - **Cruise:(-)**
 - Cruise_ID: (EXPOCODE)
 - Section: (Leg)
 - **Geographical Coverage:***
 - Geographical_Region:
 - **Bounds:**
 - Westernmost_Longitude:
Enter decimal fractions of degrees:
or Degrees, Minutes, Seconds:
 - Easternmost_Longitude:
Enter decimal fractions of degrees: [-144.83](#) (+ = E, - = W)
or Degrees, Minutes, Seconds:
 - Northernmost_Latitude:
Enter decimal fractions of degrees: [+50.13](#) (+ = E, - = W)
 - Southernmost_Latitude:
Enter decimal fractions of degrees:
 - **Temporal Coverage:**
 - Start_Date: [20090613](#) (YYYYMMDD)
 - End_Date: [20100327](#) (YYYYMMDD)
 - **Vessel:*** [Mooring platform](#)
 - Vessel_Name:
 - Vessel_ID:
 - Country:
 - Vessel_Owner:
- **Variables Info:***
 - **Variable:**
 - Variable_Name and Description*:
- [xCO₂ SW \(wet\) \(umol/mol\) - Mole fraction of CO₂ in air in equilibrium with the seawater at sea surface temperature and measured humidity.](#)
- [CO₂ SW QF – Quality Flag for xCO₂ SW \(wet\).](#)
- [H₂O SW \(mmol/mol\) - Mole fraction of H₂O in air from equilibrator .](#)
- [xCO₂ Air \(wet\) \(umol/mol\) - Mole fraction of CO₂ in air from airblock, 4 feet above the sea surface at measured humidity.](#)
- [CO₂ Air QF – Quality Flag for xCO₂ Air \(wet\)](#)
- [H₂O Air \(mmol/mol\) - Mole fraction of H₂O in air from airblock, 4 feet above the sea surface.](#)

- Licor Atm Pressure (hPa) – Atmospheric pressure at the airblock, 4 feet above the sea surface
- Licor Temp (C) – Temperature of the Infrared Licor 820 in degrees Celsius
- % O₂ - The percent oxygen of the surface seawater divided by the percent oxygen of the atmosphere at 4 feet above the sea surface. Disclaimer: The oxygen measurement is made in the equilibrated air. We have found that the oxygen does not come to complete equilibrium so any rapid changes in oxygen do not get properly captured using this system. Therefore, we tend to use the oxygen data only as a qualitative sense of the biology. It is not a quantitative measure.
- SST (C) – Sea Surface Temperature collected by NOAA/PMEL/Papa. provide internally recorded SST data at 10 minute resolution. The sea surface temperature collected during the equilibration period is reported in this dataset. NOAA/PMEL/Papa advises to check the Papa site at the time of use for the most accurate data available.
- Salinity – Sea Surface Salinity collected by NOAA/PMEL/Papa. Papa records conductivity data at 10 minute intervals and then computes hourly averaged salinity during post-processing. The salinity reported during the equilibration period is reported in this dataset. NOAA/PMEL/Papa advises to check the Papa site at the time of use for the most accurate data available.
- xCO₂ SW (dry) (umol/mol) – Mole fraction of CO₂ in air in equilibrium with the seawater at sea surface temperature (dry air).
- xCO₂ Air (dry) (umol/mol) – Mole fraction of CO₂ in air at the airblock, 4 feet above the sea surface (dry air).
- fCO₂ SW (sat) uatm – Fugacity of CO₂ in air in equilibrium was not calculated during this deployment since SST and SSS was not available.
- fCO₂ Air (sat) uatm – Fugacity of CO₂ in air was not calculated during this deployment since SST and SSS was not available.
- dfCO₂ – Difference of the fugacity of the CO₂ in seawater and the fugacity of the CO₂ in air (fCO₂ SW - fCO₂ Air) was not calculated during this deployment since SST and SSS was not available.

- **Method_Description:***

- **Equilibrator_Design:**

- Equilibrator_Type: (show pick list) Bubble Equilibrator
 - Equilibrator_Volume: (L) N/A
 - Water_Flow_Rate: (L/min) N/A
 - Headspace_Gas_Flow_Rate: (L/min) ~600 cc/min
 - Vented: (show pick list) Yes

- Measurement_Method: Absolute, non-dispersive infrared (NDIR) gas analyzer

- Manufacturer_of_Calibration_Gas: NOAA Earth System Research Laboratory (ESRL)

- **CO₂_Sensors:**

- **CO₂_Sensor:**

- Manufacturer: Licor
 - Model: Environmental_Control: LI-820
 - Resolution: 0.01 ppm
 - Uncertainty: < 2.5% of reading with 14 cm bench (stated)
<1.5 ppm determined in lab
 - CO₂_Sensor_Calibration: (For each calibration gas, document traceability to an internationally recognized scale, including date and place of last calibration. Include uncertainty of assigned value.)

At the beginning of each sample, the instrument self-calibrates using a zero and high standard. The zero standard is generated by cycling a small amount of air through a soda lime chamber. The high standard is from a cylinder of calibrated standard reference gas, 437.13 umol/mol, from ESRL. ESRL

standards are traceable to WMO x93 scale with a stated reproducibility of 0.06 micromole/mole.

- **Other_Sensors:**
 - Manufacturer: Oxygen Sensor
 - Model: Maxtec
 - Resolution: Max-250
 - Uncertainty: 0.01 %
 - range: $\pm 2.0\%$ Full Scale over operating temperature
 - pressure: $\pm 1.0\%$ Full Scale @ constant temperature and pressure
 - Calibration: (For each sensor of pressure, temperature, and salinity, document traceability to an internationally recognized scale, including date and place of last calibration.)
Factory calibrated before purchase. Recalibrated to sea level atmospheric air every 7 days.
- **Other_Sensors:**
 - Manufacturer: Humidity Sensor
 - Model: Sensirion
 - Resolution: SHT71
 - Uncertainty: 0.01 %
 - Measurement range: 0-100% RH
 - Absolute RH accuracy: $\pm 3\%$ RH (20-80% RH)
 - Repeatability RH: $\pm 0.1\%$ RH
 - Calibration: (For each sensor of pressure, temperature, and salinity, document traceability to an internationally recognized scale, including date and place of last calibration.)
Factory calibrated before purchase.
- Method_References: (Publication(s) describing method)

Sabine, C. (2005): High-resolution ocean and atmosphere pCO₂ time-series measurements. The State of the Ocean and the Ocean Observing System for Climate, Annual Report, Fiscal Year 2004, NOAA/OGP/Office of Climate Observation, Section 3.32a, 246–253.

- Additional Information

- All measurements are at sea surface temperature and atmospheric pressure.
- During the equilibration cycle, a closed loop of air equilibrates with seawater for 10 minutes. Once the equilibration period is complete, the pump stops and the system opens to the atmosphere allowing the pressure to equilibrate with atmospheric pressure. Measurements are recorded for 30 seconds at 2 hertz and then averaged.
- During the air cycle, fresh air is pumped through the detector for 1 minute. Once the pump stops, the system opens to the atmosphere allowing the pressure to equilibrate with atmospheric pressure. Measurements are recorded for 30 seconds at 2 hertz and then averaged.
- The gas streams for both the air cycle and equilibrator cycle are partially dried before entering the detector. The values listed as wet xCO₂ generally have relative humidity levels ranging from 40 to 80 percent. The humidity levels increase over the course of a deployment.
- Sampling occurs every 3 hours. The infrared detector is calibrated at the beginning of every sampling period. Averaged data and standard deviations for each measurement are transmitted back daily.
- To calculate the dry measurements, the water mole fraction in the Licor detector must be known. A relative humidity sensor is located immediately downstream of the detector.

- As part of the QC process, each data set is compared with the Marine Boundary Layer (MBL) data from GlobalView-CO₂. The data from this deployment, June 2009 to Mar 2010, were -0.6 ± 1.1 $\mu\text{mol/mol}$ on average of the MBL data and therefore no correction was applied.

GLOBALVIEW-CO₂: Cooperative Atmospheric Data Integration Project - Carbon Dioxide. CD-ROM, NOAA ESRL, Boulder, Colorado [Also available on Internet via anonymous FTP to ftp.cmdl.noaa.gov, Path: ccg/co2/GLOBALVIEW], 2010

-During the QC process, an adjustment to the Licor pressure is also made based on each sensor's bias to barometric pressure as measured in the lab. For this system, the Licor pressure was adjusted by +0.16 kPa.

- This deployment ended early when water got inside of the buoy well and likely damaged the battery in late March 2010.

- No data = -9.999 or -999

• Data_set_References: (Publication(s) describing data set) None

• Citation: (How to cite this data set) Sabine, C., S. Maenner and A. Sutton. 2010. High-resolution ocean and atmosphere pCO₂ time-series measurements from mooring Papa.

• Data_Set_Link:

○ URL*: http://www.pmel.noaa.gov/co2/moorings/papa/papa_main.htm

○ Label*: PMEL CO₂ Group - Papa mooring

○ Link_Note: (Optional instructions or remarks)(m s t)

Quality Flags definitions:

- 2 = Acceptable measurement;
- 3 = Questionable measurement;
- 4 = Bad measurement
- 5 = Not reported;
- 9 = Sample not drawn for this measurement from this bottle.

Quality Flag Log for this dataset.

Date	Measurement	Value (Dry)	Flag	Comments
6/26/2009 9:17	xCO ₂ _Air	387.3502965	3	CO ₂ data submitted was adjusted by - 18 ppm b/c span calibration was off as predicted by change in Licor temperature
10/28/2009 3:17	xCO ₂ _Air	385.4252677	3	CO ₂ data submitted was adjusted by - 18 ppm b/c span calibration was off as predicted by change in Licor temperature
11/5/2009 6:17	xCO ₂ _SW	383.5701362	4	likley bad CO ₂ sw measurement due to equil pressure problem
11/8/2009 21:17	xCO ₂ _SW	371.8099948	3	bad CO ₂ sw measurement due to equil pressure problem
2/16/2010 0:17	xCO ₂ _SW	377.027191	4	bad CO ₂ sw measurement due to equil pressure problem