

VALENCIA, SP

Latitude = 39.49 N

Longitude = 0.48 W

Period of Record = 1988 To 2017

Station ID = ICAO_LEVC

Elevation = 69 Meters

Average Pressure = 1010 mb

Design Criteria Data

Dry Bulb Temperature (T)	Mean Coincident (Average) Values				
	Design Value (°C)	Wet Bulb Temperature (°C)	Humidity Ratio (g/kg)	Wind Speed (m/s)	Prevailing Direction (NSEW)
Median of Extreme Highs	37	20	7	7	W
0.4% Occurrence	33	21	10	4.9	ESE
1.0% Occurrence	32	22	12	4.5	E
2.0% Occurrence	31	22	13	4.4	E
Mean Daily Range	10	-	-	-	W
97.5% Occurrence	4	3	4	2.2	W
99.0% Occurrence	2	1	4	2.2	W
99.6% Occurrence	1	0	3	2.2	W
Median of Extreme Lows	-2	-3	2	2.3	W

Wet Bulb Temperature (T _{wb})	Design Value (°C)	Dry Bulb Temperature (°C)	Humidity Ratio (g/kg)	Wind Speed (m/s)	Prevailing Direction (NSEW)
Median of Extreme Highs	30	30	-	4.6	ESE
0.4% Occurrence	26	29	18	3.8	E
1.0% Occurrence	25	28	17	3.5	E
2.0% Occurrence	24	28	16	3.3	E

Humidity Ratio (HR)	Design Value (g/kg)	Dry Bulb Temperature (°C)	Vapor Pressure (kPa)	Wind Speed (m/s)	Prevailing Direction (NSEW)
Median of Extreme Highs	19	28	100.65	2.8	E
0.4% Occurrence	18	27	95.92	2.9	E
1.0% Occurrence	18	27	93.42	3	E
2.0% Occurrence	17	27	90.74	2.8	E

Air Conditioning/ Humid Area Criteria	Threshold	T ≥ 33.9 °C	T ≥ 26.7 °C	Twb ≥ 22.8 °C	Twb ≥ 19.4 °C
	# of Hours	28	1001	453	1792


Other Site Data

Weather Region	Rain Rate 100 Year Recurrence (cm/hr)	Basic Wind Speed 3 sec gust @ 10 m 50 Year Recurrence (m/s)	Ventilation Cooling Load Index (kWh/l/s/yr) Base 24° C-RH 60% Latent + Sensible
8	N/A	N/A	1.4 + 0.6
Ground Water Temperature (°C) 15 Meter Depth*	Frost Depth 50 Year Recurrence (cm)	Ground Snow Load 50 Year Recurrence (kN/m ²)	Average Annual Freeze-Thaw Cycles (#)
18.9	N/A	N/A	4


*Note: Temperatures at greater depths can be estimated by adding 0.83° C per 30 meters additional depth.




Average Annual Climate



Long Term Psychrometric Summary



Psychrometric Summary of Peak Design Values



	(°C) / (g/kg)	MCDB (°C)	MCWB (°C)	MCDP (°C)	MCHR (g/kg)	Enthalpy (kJ/kg)
1.0% Dry Bulb	32.0		22		12.0	62.4
99.0% Dry Bulb	2.0				4.0	11.0
1.0% Humidity Ratio	18.0	27.0	24	22.8		72.2

Dry-Bulb Temperature Hours For An Average Year

	January					February					March				
Temperature Range (°C)	01 To 08 LST	09 To 16 LST	17 to 00 LST	Total Obs	M C W B (°C)	01 To 08 LST	09 To 16 LST	17 to 00 LST	Total Obs	M C W B (°C)	01 To 08 LST	09 To 16 LST	17 to 00 LST	Total Obs	M C W B (°C)
42/ 44															
39/ 41															
36/ 38															
33/ 35															
30/ 32												0	0	0	16.1
27/ 29							0	0	0	15.8		2	1	3	15.7
24/ 26		0		0	13.3		1	0	1	14.5		7	3	10	14.6
21/ 23		6	1	7	13.1		8	3	11	13		26	11	37	13.3
18/ 20	1	16	6	23	12.1	1	22	10	33	11.9	1	42	21	64	12.2
15/ 17	11	59	31	101	10.6	8	58	34	100	10.4	14	79	64	157	11.3
12/ 14	22	64	60	146	9.4	24	58	64	146	9.3	46	52	85	183	10.2
9/ 11	40	42	66	148	8	46	37	58	141	7.9	71	27	43	141	8.4
6/ 8	80	38	61	179	5.8	79	29	43	151	5.7	87	12	20	119	6
3/ 5	53	14	18	85	3.3	41	8	9	58	3.1	23	1	2	26	3.1
0/ 2	37	8	5	50	0.8	24	3	2	29	0.4	5	0	0	5	0.3
-3/ -1	4	1	0	5	-2.7	2	0		2	-3.2	1			1	-2
-6/ -4	0	0		0	-5.8										

Caution: This summary reflects the typical distribution of temperature in a typical year. It does not reflect the typical moisture distribution. Because wet bulb temperatures are averaged, this summary understates the annual moisture load. For accurate moisture load data, see the long-term humidity summary and the ventilation and infiltration load pages in this manual.

Dry-Bulb Temperature Hours For An Average Year

	April					May					June				
Temperature Range (°C)	01 To 08 LST	09 To 16 LST	17 to 00 LST	Total Obs	M C W B (°C)	01 To 08 LST	09 To 16 LST	17 to 00 LST	Total Obs	M C W B (°C)	01 To 08 LST	09 To 16 LST	17 to 00 LST	Total Obs	M C W B (°C)
42/ 44							0		0	19					
39/ 41							0	0	0	18.9					
36/ 38							0	0	0	17.3		1	1	2	19.2
33/ 35		0		0	16.5		1	0	1	18.4		3	1	4	19.8
30/ 32		0	0	0	17.5	0	5	1	6	17.7		27	8	35	19.9
27/ 29		2	1	3	15.9	0	15	4	19	17.3	1	67	26	94	19.7
24/ 26		13	4	17	14.8	0	47	14	61	16.6	7	76	58	141	19.1
21/ 23	0	50	18	68	13.9	5	94	63	162	16	65	53	102	220	18.3
18/ 20	3	65	38	106	13	33	53	76	162	15.2	91	10	33	134	16.7
15/ 17	30	73	97	200	12.1	112	27	73	212	13.8	67	3	11	81	14.6
12/ 14	87	28	62	177	10.7	72	5	13	90	11.4	9	0	1	10	11.7
9/ 11	77	7	17	101	8.8	20	1	3	24	9	0			0	9.5
6/ 8	38	1	3	42	6.3	5	0	0	5	6.5					
3/ 5	3	0		3	3.7	0			0	2.5					
0/ 2															
-3/ -1															
-6/ -4															

Caution: This summary reflects the typical distribution of temperature in a typical year. It does not reflect the typical moisture distribution. Because wet bulb temperatures are averaged, this summary understates the annual moisture load. For accurate moisture load data, see the long-term humidity summary and the ventilation and infiltration load pages in this manual.

Dry-Bulb Temperature Hours For An Average Year

	July					August					September				
Temperature Range (°C)	01 To 08 LST	09 To 16 LST	17 to 00 LST	Total Obs	M C W B (°C)	01 To 08 LST	09 To 16 LST	17 to 00 LST	Total Obs	M C W B (°C)	01 To 08 LST	09 To 16 LST	17 to 00 LST	Total Obs	M C W B (°C)
42/ 44		0		0	20		0	0	0	19.6					
39/ 41		0	0	0	18.9		0	0	0	19.9					
36/ 38		1	1	2	20		2	1	3	19.8		1	0	1	19.1
33/ 35		7	2	9	20.6	0	9	2	11	21.2		2	1	3	19.4
30/ 32	0	76	21	97	21.9	0	86	24	110	22.5		19	5	24	20.3
27/ 29	2	105	69	176	21.6	3	97	79	179	22.2	0	66	22	88	20.7
24/ 26	41	46	107	194	21.1	55	41	109	205	21.6	6	74	65	145	19.9
21/ 23	150	12	47	209	19.6	152	11	30	193	19.8	76	55	102	233	19
18/ 20	47	0	3	50	17.2	34	1	3	38	17.1	86	18	32	136	17
15/ 17	9	0	0	9	15.3	5	0	0	5	14.7	61	6	12	79	14.5
12/ 14						0			0	10.5	10	0	1	11	11.5
9/ 11											1		0	1	8.4
6/ 8															
3/ 5															
0/ 2															
-3/ -1															
-6/ -4															

Caution: This summary reflects the typical distribution of temperature in a typical year. It does not reflect the typical moisture distribution. Because wet bulb temperatures are averaged, this summary understates the annual moisture load. For accurate moisture load data, see the long-term humidity summary and the ventilation and infiltration load pages in this manual.

Dry-Bulb Temperature Hours For An Average Year

	October					November					December				
Temperature Range (°C)	01 To 08 LST	09 To 16 LST	17 to 00 LST	Total Obs	M C W B (°C)	01 To 08 LST	09 To 16 LST	17 to 00 LST	Total Obs	M C W B (°C)	01 To 08 LST	09 To 16 LST	17 to 00 LST	Total Obs	M C W B (°C)
42/ 44															
39/ 41															
36/ 38															
33/ 35		0	0	0	19.1										
30/ 32		4	1	5	18.6		0	0	0	18.9					
27/ 29		15	3	18	18.3		1	0	1	16.7					
24/ 26	0	42	12	54	18.1		4	1	5	15.6		0		0	15.5
21/ 23	7	86	67	160	17.2	1	28	7	36	14.8		5	1	6	14.2
18/ 20	38	52	74	164	15.9	4	50	23	77	13.8	2	21	6	29	12.8
15/ 17	117	38	72	227	14.2	35	80	80	195	12.5	10	70	37	117	11.2
12/ 14	64	9	16	89	11.4	60	45	68	173	10.5	31	64	68	163	9.8
9/ 11	16	1	2	19	8.7	59	20	35	114	8.5	51	42	62	155	8.3
6/ 8	4	0	1	5	5.6	58	10	21	89	5.8	76	29	53	158	5.9
3/ 5	1			1	2.5	17	2	3	22	3	45	11	17	73	3.2
0/ 2						6	0	1	7	0.4	29	5	5	39	0.7
-3/ -1						1			1	-2.9	4	0	0	4	-2.8
-6/ -4											0			0	-5.1


Caution: This summary reflects the typical distribution of temperature in a typical year. It does not reflect the typical moisture distribution. Because wet bulb temperatures are averaged, this summary understates the annual moisture load. For accurate moisture load data, see the long-term humidity summary and the ventilation and infiltration load pages in this manual.

Dry-Bulb Temperature Hours For An Average Year


	Annual				
Temperature Range (°C)	01 To 08 LST	09 To 16 LST	17 to 00 LST	Total Obs	M C W B (°C)
42/ 44		0	0	0	19.6
39/ 41		1	0	1	19.5
36/ 38		5	2	7	19.6
33/ 35	0	21	6	27	20.5
30/ 32	0	217	59	276	21.6
27/ 29	5	369	205	579	21
24/ 26	109	352	373	834	19.9
21/ 23	456	435	452	1343	17.9
18/ 20	339	351	324	1014	15.2
15/ 17	479	493	512	1484	12.6
12/ 14	425	326	436	1187	10.3
9/ 11	382	178	286	846	8.3
6/ 8	428	121	202	751	5.9
3/ 5	182	36	49	267	3.2
0/ 2	102	16	13	131	0.6
-3/ -1	11	1	0	12	-2.8
-6/ -4	1	0		1	-5.5

Caution: This summary reflects the typical distribution of temperature in a typical year. It does not reflect the typical moisture distribution. Because wet bulb temperatures are averaged, this summary understates the annual moisture load. For accurate moisture load data, see the long-term humidity summary and the ventilation and infiltration load pages in this manual.

Annual Summary of Temperatures




Long Term Humidity and Dry Bulb Temperature Summary



Long Term Humidity and Dry Bulb Temperature Summary


Week Ending	1.0% Temp (°C)	MCWB@ 1% Temp (°C)	Mean Max Temp (°C)	Mean Min Temp (°C)	99% Temp (°C)	1.0% HR (g/kg)	MCDB@ 1% HR (°C)	Mean Max HR (g/kg)	Mean Min HR (g/kg)
7-Jan	21.1	12.8	16	5.7	0.6	8.3	15.6	6.5	4.3
14-Jan	20.6	12.7	15.7	5.2	0	8.2	13.3	6.5	4.3
21-Jan	19.4	11.4	15.4	5.2	0.6	8.9	13.7	6.4	4.3
28-Jan	21.1	13.3	15.7	5.7	-1.1	8.6	14.8	6.3	4.2
4-Feb	21.1	12.7	15.9	5.5	0.6	8.5	13.8	6.4	4.2
11-Feb	20.6	12.7	16.5	5.9	0.6	8.2	13.6	6.4	4.2
18-Feb	22.8	13.7	16.6	6.3	0.6	8.3	16.4	6.4	4.2
25-Feb	22.2	12.8	16.9	6.4	2.2	8.4	13.1	6.6	4.4
4-Mar	24.4	14.1	17.4	7.2	1.7	8.5	15.4	6.5	4.2
11-Mar	23.9	15.4	18.2	7.3	2.8	9.2	17.2	6.9	4.5
18-Mar	24.4	13.1	18.5	7.6	3.3	9	14.7	7.4	4.9
25-Mar	26.1	14.9	19.5	8.7	5	9.6	17.2	7.7	5.1
1-Apr	26.1	14.4	19.8	9.3	6.1	9.3	14.7	7.6	5
8-Apr	25	14.3	19.9	9.5	6.1	9.4	16.1	7.8	5.1
15-Apr	25.6	14.4	20.4	9.8	6.7	9.9	17.2	8	5.2
22-Apr	25.6	14.1	20.7	10.7	7.2	10.3	17.1	8.2	5.5
29-Apr	26.7	15.7	21.9	11.2	7.8	10.7	19.2	8.7	5.8
6-May	27.8	16.3	21.9	11.7	7.8	11.5	19.8	9	6
13-May	30	17.1	23.3	13.1	10	12	19.3	10.1	7
20-May	28.9	18.7	24.4	13.9	10.6	12.4	20.3	10.2	6.9
27-May	28.9	17.7	24.9	14.7	11.7	12.8	21.1	10.8	7.4
4-Jun	31.1	17.9	26.3	15.9	12.8	13.8	23.6	11.5	7.9
10-Jun	30.6	18.2	26.3	16.7	13.3	14.7	23.8	12.2	8.6
17-Jun	32.8	19.4	27.8	17.5	14.4	15.3	25.4	12.5	8.5
24-Jun	32.8	20.4	28.5	18.4	15.6	16	25.8	13.5	9.1
1-Jul	33.3	18.9	29.1	19.4	16.7	17.6	27	14.3	9.9
8-Jul	33.9	19.4	29.8	20.2	17.2	17.1	25.8	14.8	10.1
15-Jul	32.8	21.1	29.5	20.3	17.8	17.1	25.8	15.1	10.7
22-Jul	33.3	20.6	30.4	20.9	18.9	18.2	28.1	15.6	11
29-Jul	35	20.2	31	21.6	19.4	18.9	27.6	16.5	11.6
5-Aug	33.9	22.6	30.8	21.7	19.4	18.8	27.7	16.5	11.7
12-Aug	34.4	21.4	30.9	21.4	18.9	18.9	28.1	16.2	11.2
19-Aug	33.9	20.4	30.7	21.3	18.9	18.9	27.5	16.5	11.7
26-Aug	35	19.8	30.7	21.3	18.3	18.9	27.6	16.4	11.1
2-Sep	32.8	21.9	29.6	20.9	17.8	18.9	27.7	15.7	11.2
9-Sep	32.8	19.6	29.1	19.7	17.2	18.2	26.5	15.1	10.3
16-Sep	32.2	19.7	28.4	18.6	15	17.6	25.7	14.2	9.6
23-Sep	30	19.7	26.8	17.5	13.9	16.3	24.3	13.3	9.3
30-Sep	29.4	18.6	25.7	16.6	12.8	15.9	23.5	12.6	8.7
7-Oct	29.4	18.4	25.8	15.8	12.8	15.8	24.1	12.2	8.3
14-Oct	29.4	18.8	24.4	15.1	12.2	14.8	22.9	11.6	7.9
21-Oct	27.8	18.6	23.5	14.1	10	13.8	21.9	11	7.6
28-Oct	27.8	17.8	22.8	13.4	8.9	13.7	21.7	10.7	7.4
4-Nov	26.1	16.8	22.1	12	7.2	12.8	20.9	9.9	6.6
11-Nov	23.9	15.4	20	10.6	6.1	11.5	17.9	8.5	5.8
18-Nov	23.3	14.8	19.3	9.1	2.8	10.7	17.9	8	5.5
25-Nov	22.2	14.5	18	8.1	2.2	10.7	17.3	7.5	5.1
2-Dec	21.1	13.5	16.8	7.5	1.7	10.2	16.2	7.2	4.9
9-Dec	20.6	13.1	16.7	6.9	1.1	9.3	14.2	7	4.8
16-Dec	20.6	13.9	16	6.1	0.6	9.1	14.9	6.7	4.6
23-Dec	20.6	12.7	15.9	5.8	0	9	15.2	6.7	4.6
31-Dec	20	13.6	15.9	5.7	-0.6	8.9	15	6.4	4.3

Degree Days, Heating and Cooling (Base 18.3 C) & Cooling (Base 10 C)



Month	Mean Cooling Degree Days (°C) Base 10	Mean Cooling Degree Days (°C) Base 18.3	Mean Heating Degree Days (°C) Base 18.3
JAN	61	2	256
FEB	69	4	210
MAR	120	12	170
APR	170	22	107
MAY	279	65	45
JUN	390	147	7
JUL	487	229	0
AUG	498	240	0
SEP	383	141	7
OCT	274	60	44
NOV	130	11	147
DEC	69	2	239
ANN	2930	933	1233

Average Ventilation and Infiltration Loads (Outside Air vs 24C, 60% RH summer; 20C, 30% RH winter)



Month	Average Sensible Cooling Load (kWh/l/s)	Average Sensible Heating Load (kWh/l/s)	Average Latent Cooling Load (kWh/l/s)	Average Latent Heating Load (kWh/l/s)
JAN	1	-8881	0	-566
FEB	4	-7384	0	-643
MAR	31	-6235	0	-407
APR	46	-4231	1	-154
MAY	269	-2082	155	-34
JUN	1107	-472	1627	-2
JUL	2241	-52	5105	-1
AUG	2460	-35	6472	-2
SEP	954	-480	3001	-4
OCT	226	-2105	590	-29
NOV	14	-5539	16	-277
DEC	0	-8389	0	-487
ANN	7352	-45883	16966	-2606

Station Information		Shading Geometry in Dimensionless Units	
City, State, WBAN	N/A	N/A	N/A
Lat, Lon, Elev	N/A	N/A	N/A
Press Stn Type	N/A	N/A	N/A

AVERAGE INCIDENT SOLAR RADIATION (Btu/sq.ft./day), Percentage Uncertainty = 9														
		Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Year
HORIZ.	Global													
	Std.Dev.													
	Minimum													
	Maximum													
	Diffuse													
Clear Day	Global													
NORTH	Global													
	Diffuse													
Clear Day	Global													
EAST	Global													
	Diffuse													
Clear Day	Global													
SOUTH	Global													
	Diffuse													
Clear Day	Global													
WEST	Global													
	Diffuse													
Clear Day	Global													


Average Annual Solar Radiation - Nearest Available Site
Source: National Renewable Energy Laboratory, Golden CO, 1995

AVERAGE TRANSMITTED SOLAR RADIATION (Btu/sq.ft./day) FOR DOUBLE GLAZING, Percentage Uncertainty = 9														
		Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Year
HORIZ.	Unshaded													
NORTH	Unshaded													
	Shaded													
EAST	Unshaded													
	Shaded													
SOUTH	Unshaded													
	Shaded													
WEST	Unshaded													
	Shaded													


AVERAGE INCIDENT ILLUMINENCE (klux-hr) FOR MOSTLY CLEAR AND MOSTLY CLOUDY CONDITIONS, Percentage Uncertainty = 9											
		March			June						
		9am	11am	1pm	3pm	5pm	9am	11am	1pm	3pm	5pm
HORIZ.	M.Clear										
	M.Cloudy										
NORTH	M.Clear										
	M.Cloudy										
EAST	M.Clear										
	M.Cloudy										
SOUTH	M.Clear										
	M.Cloudy										
WEST	M.Clear										
	M.Cloudy										
M.Clear	(% hrs)										

		Sept						Dec			
		9am	11am	1pm	3pm	5pm	9am	11am	1pm	3pm	5pm
HORIZ.	M.Clear										
	M.Cloudy										
NORTH	M.Clear										
	M.Cloudy										
EAST	M.Clear										
	M.Cloudy										
SOUTH	M.Clear										
	M.Cloudy										
WEST	M.Clear										
	M.Cloudy										
M.Clear	(% hrs)										


Wind Summary - December, January, and February



Wind Summary - March, April, and May



Wind Summary - June, July, and August



Wind Summary - September, October, and November

