

BERMUDA NAS/KINDLEY BE

Latitude = 32.37 N

WMO No. 780160

Longitude = 64.68 W

Elevation = 10 feet

Period of Record = 1967 to 1996

Average Pressure = 30.03 inches Hg

Design Criteria Data

	Design Value	Mean Coincident (Average) Values			
		Wet Bulb Temperature (°F)	Humidity Ratio (gr/lb)	Wind Speed (mph)	Prevailing Direction (NSEW)
Dry Bulb Temperature (T)	(°F)				
Median of Extreme Highs	90	78	125	10.0	S
0.4% Occurrence	88	78	126	10.3	S
1.0% Occurrence	87	77	124	10.4	S
2.0% Occurrence	86	77	123	10.4	S
Mean Daily Range	8	-	-	-	-
97.5% Occurrence	58	52	46	13.6	WNW
99.0% Occurrence	56	50	44	14.8	WNW
99.6% Occurrence	54	49	42	16.3	WNW
Median of Extreme Lows	50	46	41	20.8	W
	Design Value	Mean Coincident (Average) Values			
		Dry Bulb Temperature (°F)	Humidity Ratio (gr/lb)	Wind Speed (mph)	Prevailing Direction (NSEW)
Wet Bulb Temperature (T_{wb})	(°F)				
Median of Extreme Highs	82	86	154	10.7	SSW
0.4% Occurrence	80	85	142	11.1	SSW
1.0% Occurrence	79	84	137	11.4	SSW
2.0% Occurrence	78	83	133	11.2	SSW
	Design Value	Mean Coincident (Average) Values			
		Dry Bulb Temperature (°F)	Vapor Pressure (in. Hg)	Wind Speed (mph)	Prevailing Direction (NSEW)
Humidity Ratio (HR)	(gr/lb)				
Median of Extreme Highs	167	84	1.11	7.6	ESE
0.4% Occurrence	148	84	0.99	10.3	SW
1.0% Occurrence	141	82	0.94	12.4	SSW
2.0% Occurrence	139	83	0.94	10.9	SSW
Air Conditioning/ Humid Area Criteria	# of Hours	T ≥ 93°F	T ≥ 80°F	T _{wb} ≥ 73°F	T _{wb} ≥ 67°F
		0	1775	2337	4242

Other Site Data


Weather Region	Rain Rate 100 Year Recurrence (in./hr)	Basic Wind Speed 3 sec gust @ 33 ft 50 Year Recurrence (mph)	Ventilation Cooling Load Index (Ton-hr/cfm/yr) Base 75°F-RH 60% Latent + Sensible
10	N/A	N/A	7.6 + 1.6
Ground Water Temperature (°F) 50 Foot Depth *	Frost Depth 50 Year Recurrence (in.)	Ground Snow Load 50 Year Recurrence (lb/ft ²)	Average Annual Freeze-Thaw Cycles (#)
74.8	N/A	N/A	0

*Note: Temperatures at greater depths can be estimated by adding 1.5°F per 100 feet additional depth.


BERMUDA NAS/KINDLEY BE

WMO No. 780160

Average Annual Climate




Long Term Psychrometric Summary



- 50% of all observations
- 80% of all observations
- 95% of all observations
- 97.5% of all observations
- 99% of all observations

Psychrometric Summary of Peak Design Values



99% Dry Bulb	(°F)	MCHR (gr/lb)	Enthalpy (btu/lb)	1.0% Humidity Ratio	(gr/lb)	MCDB (°F)	MCWB (°F)	MC Dewpt (°F)	Enthalpy (btu/lb)
	56	44.1	20.3		140.7	82.2	78.4	77	41.8

1.0% Dry Bulb	(°F)	MCHR (gr/lb)	MCWB (°F)	Enthalpy (btu/lb)
	87	124.1	77.3	40.4

BERMUDA NAS/KINDLEY BE

WMO No. 780160

Dry-Bulb Temperature Hours For An Average Year (Sheet 1 of 5)

Period of Record = 1967 to 1996

Temperature Range (°F)	January					February					March				
	Hour Group (LST)			Total Obs	M C W B (°F)	Hour Group (LST)			Total Obs	M C W B (°F)	Hour Group (LST)			Total Obs	M C W B (°F)
	01 To 08	09 To 16	17 To 00			01 To 08	09 To 16	17 To 00			01 To 08	09 To 16	17 To 00		
90 / 94															
85 / 89															
80 / 84	0	0		0	69.3		0		0	69.0	0	0	0	0	70.0
75 / 79	0	5	0	6	67.8	0	3	0	3	66.7	0	6	0	6	68.0
70 / 74	32	78	41	151	65.1	16	60	25	100	64.9	18	79	31	128	64.9
65 / 69	82	82	85	249	61.0	61	71	70	203	61.4	76	84	88	249	61.5
60 / 64	93	63	88	243	55.9	96	68	88	252	56.1	106	62	95	263	56.1
55 / 59	35	16	29	80	51.2	43	20	37	100	51.0	44	14	31	89	50.9
50 / 54	7	2	5	14	47.7	8	2	4	13	48.1	4	1	3	9	47.6
45 / 49	0	0	0	0	44.4	0	0	0	1	44.9	0	0		0	44.0

Caution: This summary reflects the typical distribution of temperature in a typical year. It does not reflect the typical moisture distribution. Because wet bulb temperatures are averaged, this summary understates the annual moisture load. For accurate moisture load data, see the long-term humidity summary and the ventilation and infiltration load pages in this manual.

BERMUDA NAS/KINDLEY BE

WMO No. 780160

Dry-Bulb Temperature Hours For An Average Year (Sheet 2 of 5)

Period of Record = 1967 to 1996

Temperature Range (°F)	April					May					June				
	Hour Group (LST)			Total Obs	M C W B (°F)	Hour Group (LST)			Total Obs	M C W B (°F)	Hour Group (LST)			Total Obs	M C W B (°F)
	01 To 08	09 To 16	17 To 00			01 To 08	09 To 16	17 To 00			01 To 08	09 To 16	17 To 00		
90 / 94															
85 / 89							0		0	78.0	0	10	1	11	76.4
80 / 84	0	0	0	0	68.7	0	13	2	15	73.4	18	105	40	164	74.5
75 / 79	0	18	1	20	67.6	20	108	40	168	69.8	140	107	146	393	72.0
70 / 74	34	113	57	205	64.7	134	105	142	381	66.5	76	15	48	139	68.0
65 / 69	102	80	104	286	61.0	76	21	55	153	61.7	7	3	3	12	63.6
60 / 64	91	27	70	188	56.1	17	1	8	26	56.5	0		0	0	61.6
55 / 59	12	1	7	20	51.5	0	0	0	1	54.5					
50 / 54	1	0	0	1	49.0										
45 / 49															

Caution: This summary reflects the typical distribution of temperature in a typical year. It does not reflect the typical moisture distribution. Because wet bulb temperatures are averaged, this summary understates the annual moisture load. For accurate moisture load data, see the long-term humidity summary and the ventilation and infiltration load pages in this manual.

BERMUDA NAS/KINDLEY BE

WMO No. 780160

Dry-Bulb Temperature Hours For An Average Year (Sheet 3 of 5)**Period of Record = 1967 to 1996**

Temperature Range (°F)	July					August					September				
	Hour Group (LST)			Total Obs	M C W B (°F)	Hour Group (LST)			Total Obs	M C W B (°F)	Hour Group (LST)			Total Obs	M C W B (°F)
	01 To 08	09 To 16	17 To 00			01 To 08	09 To 16	17 To 00			01 To 08	09 To 16	17 To 00		
90 / 94		2	0	2	77.0	0	9	0	10	78.3		2		2	78.8
85 / 89	2	71	12	86	77.0	6	105	23	134	77.3	1	50	4	55	76.3
80 / 84	117	150	159	426	75.5	162	115	179	455	75.4	78	143	116	337	74.5
75 / 79	124	21	76	221	73.4	80	16	45	141	73.1	146	41	113	301	71.7
70 / 74	5	2	2	9	70.3	3	1	1	5	69.7	15	2	7	24	67.7
65 / 69		0	0	0	68.0			0	0	64.0	0	0		0	62.5
60 / 64															
55 / 59															
50 / 54															
45 / 49															

Caution: This summary reflects the typical distribution of temperature in a typical year. It does not reflect the typical moisture distribution. Because wet bulb temperatures are averaged, this summary understates the annual moisture load. For accurate moisture load data, see the long-term humidity summary and the ventilation and infiltration load pages in this manual.

BERMUDA NAS/KINDLEY BE

WMO No. 780160

Dry-Bulb Temperature Hours For An Average Year (Sheet 4 of 5)**Period of Record = 1967 to 1996**

Temperature Range (°F)	October					November					December				
	Hour Group (LST)			Total Obs	M C W B (°F)	Hour Group (LST)			Total Obs	M C W B (°F)	Hour Group (LST)			Total Obs	M C W B (°F)
	01 To 08	09 To 16	17 To 00			01 To 08	09 To 16	17 To 00			01 To 08	09 To 16	17 To 00		
90 / 94															
85 / 89		4	0	4	77.5										
80 / 84	14	85	24	123	74.0	0	7	0	7	72.5	0	0	0	0	64.3
75 / 79	128	119	136	383	70.4	24	92	36	152	69.4	3	17	3	23	69.0
70 / 74	94	34	80	209	65.6	120	103	123	347	65.1	49	105	62	217	65.0
65 / 69	11	4	8	22	60.9	72	31	64	167	60.0	93	77	98	268	60.6
60 / 64	2	0	1	3	57.9	23	6	16	45	56.3	86	42	74	203	55.8
55 / 59	0		0	0	54.0	1	0	1	3	52.5	15	6	10	32	52.3
50 / 54											1	0	1	1	50.0
45 / 49															

Caution: This summary reflects the typical distribution of temperature in a typical year. It does not reflect the typical moisture distribution. Because wet bulb temperatures are averaged, this summary understates the annual moisture load. For accurate moisture load data, see the long-term humidity summary and the ventilation and infiltration load pages in this manual.

BERMUDA NAS/KINDLEY BE


WMO No. 780160

Dry-Bulb Temperature Hours For An Average Year (Sheet 5 of 5)**Period of Record = 1967 to 1996**


Annual Totals						
Temperature Range (°F)	Hour Group (LST)			Total Obs	M C W B (°F)	
	01 To 08	09 To 16	17 To 00			
90 / 94	0	13	0	13	78.1	
85 / 89	9	237	40	286	77.0	
80 / 84	383	610	513	1506	75.0	
75 / 79	655	549	588	1793	71.3	
70 / 74	596	703	620	1918	65.6	
65 / 69	587	460	583	1629	61.1	
60 / 64	522	275	446	1243	56.0	
55 / 59	155	59	118	331	51.2	
50 / 54	21	6	13	39	47.9	
45 / 49	1	0	0	1	44.6	
</						

Caution: This summary reflects the typical distribution of temperature in a typical year. It does not reflect the typical moisture distribution. Because wet bulb temperatures are averaged, this summary understates the annual moisture load. For accurate moisture load data, see the long-term humidity summary and the ventilation and infiltration load pages in this manual.

Annual Summary of Temperatures



Long Term Humidity and Dry Bulb Temperature Summary




BERMUDA NAS/KINDLEY BE

WMO No. 780160

Long Term Dry Bulb Temperature and Humidity Summary

Week Ending	1.0% Temp (°F)	MCWB @ 1% Temp (°F)	Mean Max Temp (°F)	Mean Min Temp (°F)	99% Temp (°F)	1.0% HR (gr/lb)	MCDB @ 1% HR (°F)	Mean Max HR (gr/lb)	Mean Min HR (gr/lb)
7-Jan	75.0	68.0	69.7	62.5	55.0	102.9	70.9	79.7	54.9
14-Jan	74.0	67.0	68.9	61.5	53.0	103.6	71.5	77.4	52.7
21-Jan	73.0	66.9	68.7	61.2	53.0	102.9	71.7	76.1	52.7
28-Jan	74.0	67.5	68.9	61.4	52.0	102.9	71.6	79.1	55.3
4-Feb	74.0	67.2	68.1	60.6	54.0	102.2	72.4	74.4	52.3
11-Feb	74.0	67.1	68.0	60.1	54.0	102.2	71.4	75.8	52.4
18-Feb	73.0	66.0	68.2	60.2	53.0	98.0	70.9	74.2	51.3
25-Feb	73.0	66.6	68.9	61.3	54.0	98.0	70.5	77.4	54.9
4-Mar	73.0	66.5	67.8	59.7	52.0	102.9	70.9	74.3	50.1
11-Mar	74.0	68.5	69.4	61.2	54.0	102.9	70.6	79.5	56.6
18-Mar	73.0	65.3	68.9	60.5	54.0	102.2	70.6	77.2	52.8
25-Mar	75.0	68.3	69.4	61.2	54.0	107.1	70.5	77.9	54.2
1-Apr	74.0	66.9	69.3	61.9	55.0	109.9	71.0	76.3	54.9
8-Apr	75.0	67.2	70.6	62.5	56.0	102.9	72.2	80.9	57.2
15-Apr	75.0	68.0	70.5	62.5	57.0	103.6	71.5	78.9	56.1
22-Apr	76.0	69.6	71.4	63.6	58.0	107.1	72.2	80.1	59.0
29-Apr	76.0	67.8	72.6	64.7	59.0	109.2	73.3	83.8	61.8
6-May	77.0	68.7	73.8	66.0	62.0	111.3	72.9	88.9	68.8
13-May	79.0	70.1	74.3	66.9	62.0	114.8	73.5	90.2	70.9
20-May	79.0	70.8	76.0	68.5	64.0	123.2	76.6	98.1	77.7
27-May	82.0	74.7	77.3	70.1	66.0	132.3	76.4	104.3	84.5
3-Jun	82.0	75.2	78.5	71.3	66.0	145.6	79.4	108.2	88.2
10-Jun	84.0	76.7	79.7	72.9	66.0	140.0	81.0	114.6	95.6
17-Jun	84.0	76.2	80.6	73.5	70.0	145.6	82.1	116.2	96.3
24-Jun	86.0	75.4	81.8	74.5	70.0	142.1	81.4	121.3	100.9
1-Jul	86.0	76.6	82.7	75.5	72.0	148.4	81.8	126.3	105.7
8-Jul	88.0	78.3	83.7	76.6	73.0	148.4	83.5	128.7	108.4
15-Jul	88.0	77.6	84.6	77.2	73.0	149.1	83.5	131.6	110.8
22-Jul	88.0	77.0	85.4	78.4	75.0	148.4	83.2	130.5	110.5
29-Jul	88.0	77.4	85.5	78.3	75.0	154.0	84.2	132.7	111.0
5-Aug	89.0	78.6	86.3	78.7	75.0	157.5	85.9	132.8	112.0
12-Aug	90.0	78.3	86.5	79.0	75.0	148.4	85.6	133.6	112.9
19-Aug	90.0	78.0	86.0	78.5	75.0	150.5	84.2	133.6	111.1
26-Aug	90.0	78.6	85.7	77.8	75.0	149.1	84.1	132.4	108.1
2-Sep	88.0	78.1	85.3	77.6	73.0	149.1	84.4	128.7	105.2
9-Sep	88.0	77.7	84.8	77.1	74.0	148.4	84.0	126.8	105.2
16-Sep	88.0	77.6	84.2	76.7	73.0	149.1	83.2	127.2	103.6
23-Sep	87.0	76.7	83.6	76.0	72.0	140.7	81.5	120.9	98.8
30-Sep	86.0	75.7	83.0	75.6	73.0	140.0	82.3	119.7	96.8
7-Oct	86.0	77.4	82.0	74.6	71.0	141.4	80.5	119.1	94.0
14-Oct	84.0	75.8	80.4	73.7	68.0	141.4	80.3	113.6	89.9
21-Oct	83.0	74.0	79.7	72.4	68.0	140.7	79.5	108.5	82.2
28-Oct	82.0	73.6	78.3	71.0	66.0	133.0	78.5	104.8	80.7
4-Nov	81.0	71.5	76.9	69.8	66.0	127.4	78.2	98.1	73.3
11-Nov	81.0	73.4	76.4	69.3	63.0	128.1	77.4	99.6	74.3
18-Nov	79.0	70.5	74.9	67.4	61.0	123.2	77.5	91.3	64.5
25-Nov	78.0	69.0	73.6	66.3	61.0	116.9	74.5	88.2	62.5
2-Dec	77.0	70.0	73.1	65.7	59.0	116.2	75.7	88.6	63.8
9-Dec	77.0	68.3	71.9	64.2	58.0	115.5	74.5	84.9	59.4
16-Dec	75.0	68.5	70.8	63.4	56.0	109.9	73.0	82.6	57.8
23-Dec	75.0	68.1	70.0	62.6	57.0	102.9	71.3	78.8	54.5
31-Dec	74.0	67.0	70.0	62.9	55.0	104.3	72.7	78.7	56.4



Degree Days, Heating and Cooling
(Base 65°F)



■ Mean Cooling Degree Days ■ Mean Heating Degree Days

	Mean Cooling Degree Days (°F)	Mean Heating Degree Days (°F)
JAN	58	55
FEB	39	65
MAR	50	58
APR	81	23
MAY	200	2
JUN	340	0
JUL	450	0
AUG	478	0
SEP	407	0
OCT	298	0
NOV	171	4
DEC	81	28
ANN	2654	235


Average Ventilation and Infiltration Loads
(Outside Air vs. 75°F, 60% RH summer; 68°F, 30% RH winter)



	Average Sensible Cooling Load (Btu/cfm)	Average Sensible Heating Load (Btu/cfm)	Average Latent Cooling Load (Btu/cfm)	Average Latent Heating Load (Btu/cfm)
JAN	1	-2836	1287	-2
FEB	1	-3155	893	-3
MAR	2	-2989	1339	-2
APR	14	-1604	1607	-1
MAY	341	-262	5785	0
JUN	2126	-11	12902	0
JUL	4945	0	18924	0
AUG	5729	0	19090	0
SEP	4002	0	14679	0
OCT	1596	-25	9187	0
NOV	247	-418	3791	0
DEC	16	-1794	1796	0
ANN	19020	-13094	91280	-8

Average Annual Solar Radiation – Nearest Available Site
(Source: National Renewable Energy Laboratory, Golden CO, 1995)

No Solar Radiation
Data Available




Average Annual Solar Heat and Illumination – Nearest Available Site

(Source: National Renewable Energy Laboratory, Golden CO, 1995)

Wind Summary - December, January, and February


Labels of Percent Frequency on North Axis



Percent Calm = 2.88

Wind Summary - March, April, and May


Labels of Percent Frequency on North Axis



Percent Calm = 1.91

Wind Summary - June, July, and August


Labels of Percent Frequency on North Axis



Percent Calm = 2.17

Wind Summary - September, October, and November

Labels of Percent Frequency on North Axis



Percent Calm = 3.47