

KITZINGEN AAF, GERMANY

Latitude = 49.75 N

Longitude = 10.20 E

Period of Record = 1965 to 1994

WMO No. 106590

Elevation = 689 feet

Average Pressure = 29.25 inches Hg

Design Criteria Data

	Design Value	Mean Coincident (Average) Values			
		Wet Bulb Temperature (°F)	Humidity Ratio (gr/lb)	Wind Speed (mph)	Prevailing Direction (NSEW)
Dry Bulb Temperature (T)	(°F)				
Median of Extreme Highs	93	68	65	6.9	VARIABLE
0.4% Occurrence	88	68	73	5.5	E
1.0% Occurrence	84	67	70	5.3	E
2.0% Occurrence	81	65	69	5.4	E
Mean Daily Range	14	-	-	-	-
97.5% Occurrence	23	22	15	3.2	NNE
99.0% Occurrence	18	18	12	2.7	NNE
99.6% Occurrence	11	11	9	1.9	NNE
Median of Extreme Lows	7	7	7	0.8	SSW
	Design Value	Mean Coincident (Average) Values			
		Dry Bulb Temperature (°F)	Humidity Ratio (gr/lb)	Wind Speed (mph)	Prevailing Direction (NSEW)
Wet Bulb Temperature (T_{wb})	(°F)				
Median of Extreme Highs	74	87	105	4.7	VARIABLE
0.4% Occurrence	70	82	90	4.7	VARIABLE
1.0% Occurrence	68	80	83	4.9	VARIABLE
2.0% Occurrence	66	77	78	5.0	VARIABLE
	Design Value	Mean Coincident (Average) Values			
		Dry Bulb Temperature (°F)	Vapor Pressure (in. Hg)	Wind Speed (mph)	Prevailing Direction (NSEW)
Humidity Ratio (HR)	(gr/lb)				
Median of Extreme Highs	110	82	0.70	3.8	NNE
0.4% Occurrence	93	76	0.61	4.2	WSW
1.0% Occurrence	88	73	0.57	4.6	SW
2.0% Occurrence	83	71	0.54	5.1	SW
Air Conditioning/ Humid Area Criteria	# of Hours	T ≥ 93°F	T ≥ 80°F	T _{wb} ≥ 73°F	T _{wb} ≥ 67°F
		4	221	7	157

Other Site Data


Weather Region	Rain Rate 100 Year Recurrence (in./hr)	Basic Wind Speed 3 sec gust @ 33 ft 50 Year Recurrence (mph)	Ventilation Cooling Load Index (Ton-hr/cfm/yr) Base 75°F-RH 60% Latent + Sensible
7	N/A	N/A	0.1 + 0.2
Ground Water Temperature (°F) 50 Foot Depth *	Frost Depth 50 Year Recurrence (in.)	Ground Snow Load 50 Year Recurrence (lb/ft ²)	Average Annual Freeze-Thaw Cycles (#)
52.7	N/A	N/A	33

*Note: Temperatures at greater depths can be estimated by adding 1.5°F per 100 feet additional depth.

KITZINGEN AAF, GERMANY

WMO No. 106590


Average Annual Climate



KITZINGEN AAF, GERMANY

WMO No. 106590

Long Term Psychrometric Summary




- 50% of all observations
- 80% of all observations
- 95% of all observations
- 97.5% of all observations
- 99% of all observations

KITZINGEN AAF, GERMANY

WMO No. 106590

Psychrometric Summary of Peak Design Values



99% Dry Bulb	(°F)	MCHR (gr/lb)	Enthalpy (btu/lb)	1.0% Humidity Ratio	(gr/lb)	MCDB (°F)	MCWB (°F)	MC Dewpt (°F)	Enthalpy (btu/lb)
	18	11.8	6.1		87.5	73	66.2	62.6	31.2

1.0% Dry Bulb	(°F)	MCHR (gr/lb)	MCWB (°F)	Enthalpy (btu/lb)
	84	69.4	66.4	31.0

KITZINGEN AAF, GERMANY

WMO No. 106590

Dry-Bulb Temperature Hours For An Average Year (Sheet 1 of 5)

Period of Record = 1965 to 1994

Temperature Range (°F)	January					February					March				
	Hour Group (LST)			Total Obs	M C W B (°F)	Hour Group (LST)			Total Obs	M C W B (°F)	Hour Group (LST)			Total Obs	M C W B (°F)
	01 To 08	09 To 16	17 To 00			01 To 08	09 To 16	17 To 00			01 To 08	09 To 16	17 To 00		
95 / 99															
90 / 94															
85 / 89															
80 / 84															
75 / 79															
70 / 74												1	1	2	57.1
65 / 69												3	2	5	54.1
60 / 64		0		0	53.7		1	0	1	51.5		10	6	16	52.2
55 / 59		1	0	1	50.3	0	3	1	4	48.5	1	20	16	37	49.6
50 / 54	1	7	5	14	47.6	3	11	7	20	46.0	8	38	31	78	46.3
45 / 49	13	26	21	60	43.6	13	28	23	65	42.9	34	58	57	148	42.3
40 / 44	25	31	31	87	39.6	23	33	31	87	39.3	44	49	49	142	38.9
35 / 39	63	71	64	198	35.6	56	63	67	186	35.2	66	48	54	168	35.2
30 / 34	72	54	65	192	31.3	57	49	56	162	30.8	59	17	25	102	30.7
25 / 29	31	28	29	89	26.1	43	26	26	95	25.6	26	4	6	36	26.0
20 / 24	14	11	12	37	21.1	13	5	6	24	21.1	5	1	1	7	21.3
15 / 19	13	9	9	31	17.1	9	3	4	16	16.8	4	0	0	4	17.7
10 / 14	7	6	5	17	12.0	3	2	2	6	11.3	0	0		0	12.6
5 / 9	4	3	4	11	6.6	3	1	1	4	6.5		0		0	9.0
0 / 4	3	1	1	4	1.5	1	0	0	1	1.6					
-5 / -1	1	1	1	3	-2.9	0	0		0	-3.1					
-10 / -6	0	0	0	0	-7.3	0			0	-7.3					

Caution: This summary reflects the typical distribution of temperature in a typical year. It does not reflect the typical moisture distribution. Because wet bulb temperatures are averaged, this summary understates the annual moisture load. For accurate moisture load data, see the long-term humidity summary and the ventilation and infiltration load pages in this manual.

KITZINGEN AAF, GERMANY

WMO No. 106590

Dry-Bulb Temperature Hours For An Average Year (Sheet 2 of 5)

Period of Record = 1965 to 1994

Temperature Range (°F)	April					May					June				
	Hour Group (LST)			Total Obs	M C W B (°F)	Hour Group (LST)			Total Obs	M C W B (°F)	Hour Group (LST)			Total Obs	M C W B (°F)
	01 To 08	09 To 16	17 To 00			01 To 08	09 To 16	17 To 00			01 To 08	09 To 16	17 To 00		
95 / 99												0		0	66.0
90 / 94							0	0	0	71.0		2	1	3	68.0
85 / 89							2	1	3	66.8		6	4	10	68.0
80 / 84		1	0	1	60.4		6	4	11	63.3		17	11	27	65.4
75 / 79		2	2	5	57.9		19	14	32	60.6	0	33	25	58	63.1
70 / 74		10	6	16	55.4	0	29	23	52	58.0	4	43	34	80	61.0
65 / 69	0	13	9	22	53.4	2	32	24	58	56.0	14	34	36	83	59.2
60 / 64	1	27	21	49	51.2	14	51	46	110	53.9	50	51	57	158	56.6
55 / 59	6	37	33	76	48.8	44	52	52	148	51.4	80	39	43	163	53.3
50 / 54	33	50	52	134	46.4	76	37	51	165	48.4	60	14	25	100	49.7
45 / 49	49	53	52	154	42.4	69	16	27	112	44.3	25	2	4	31	45.5
40 / 44	53	30	33	116	39.1	26	4	5	35	40.2	5		0	5	41.5
35 / 39	63	16	26	105	35.7	14	1	1	15	36.8	1			1	37.1
30 / 34	31	2	4	37	31.1	2			2	32.3					
25 / 29	5	0	0	5	26.5										
20 / 24															
15 / 19															
10 / 14															
5 / 9															
0 / 4															
-5 / -1															
-10 / -6															

Caution: This summary reflects the typical distribution of temperature in a typical year. It does not reflect the typical moisture distribution. Because wet bulb temperatures are averaged, this summary understates the annual moisture load. For accurate moisture load data, see the long-term humidity summary and the ventilation and infiltration load pages in this manual.

KITZINGEN AAF, GERMANY

WMO No. 106590

Dry-Bulb Temperature Hours For An Average Year (Sheet 3 of 5)

Period of Record = 1965 to 1994

Temperature Range (°F)	July					August					September				
	Hour Group (LST)			Total Obs	M C W B (°F)	Hour Group (LST)			Total Obs	M C W B (°F)	Hour Group (LST)			Total Obs	M C W B (°F)
	01 To 08	09 To 16	17 To 00			01 To 08	09 To 16	17 To 00			01 To 08	09 To 16	17 To 00		
95 / 99		1	0	1	69.5		0	0	0	70.0					
90 / 94		4	3	7	68.9		3	2	5	68.3		0	0	0	65.7
85 / 89		11	8	19	67.4		7	4	11	67.7		1	0	1	65.3
80 / 84		26	18	45	66.0		24	15	40	66.0		6	3	9	66.5
75 / 79	0	35	31	66	64.0	0	41	30	71	63.5		16	8	24	63.9
70 / 74	8	50	41	99	61.6	4	52	45	101	61.7		34	20	54	61.3
65 / 69	25	38	39	102	60.0	15	42	43	100	60.1	4	35	31	69	59.2
60 / 64	68	51	60	179	57.5	73	50	60	184	57.9	25	62	56	142	56.7
55 / 59	91	30	38	158	54.2	86	24	38	149	54.5	65	56	64	185	53.6
50 / 54	48	2	9	60	50.8	56	3	9	69	50.8	78	26	45	148	50.1
45 / 49	9		0	9	46.3	13	0	1	14	46.1	48	5	12	64	45.8
40 / 44	0			0	42.5	1			1	42.4	16	1	1	18	41.7
35 / 39						0			0	39.0	5	0		5	38.0
30 / 34															
25 / 29															
20 / 24															
15 / 19															
10 / 14															
5 / 9															
0 / 4															
-5 / -1															
-10 / -6															

Caution: This summary reflects the typical distribution of temperature in a typical year. It does not reflect the typical moisture distribution. Because wet bulb temperatures are averaged, this summary understates the annual moisture load. For accurate moisture load data, see the long-term humidity summary and the ventilation and infiltration load pages in this manual.

KITZINGEN AAF, GERMANY

WMO No. 106590

Dry-Bulb Temperature Hours For An Average Year (Sheet 4 of 5)

Period of Record = 1965 to 1994

Temperature Range (°F)	October					November					December				
	Hour Group (LST)			Total Obs	M C W B (°F)	Hour Group (LST)			Total Obs	M C W B (°F)	Hour Group (LST)			Total Obs	M C W B (°F)
	01 To 08	09 To 16	17 To 00			01 To 08	09 To 16	17 To 00			01 To 08	09 To 16	17 To 00		
95 / 99															
90 / 94															
85 / 89															
80 / 84		1	0	1	65.2										
75 / 79		2	0	2	62.6										
70 / 74		7	2	9	60.5										
65 / 69		11	5	15	58.9										
60 / 64	4	35	21	61	56.3	0	2	1	3	54.5					
55 / 59	25	55	49	129	53.0	4	11	7	22	51.5	1	2	1	5	51.0
50 / 54	52	60	62	174	49.0	12	31	18	60	47.6	7	12	7	26	47.9
45 / 49	57	49	59	164	44.3	33	54	49	136	43.7	16	29	21	66	43.8
40 / 44	53	16	34	103	40.7	49	45	54	147	40.1	21	34	30	85	39.7
35 / 39	36	10	13	59	36.8	64	55	59	178	36.0	65	76	70	211	35.6
30 / 34	18	3	3	24	31.8	50	32	40	121	31.4	71	55	63	189	31.3
25 / 29	3	0	0	3	27.9	21	9	12	42	26.5	36	25	35	96	25.8
20 / 24						5	2	2	9	21.3	13	7	12	32	21.2
15 / 19						3	0	0	3	17.6	11	5	6	21	17.2
10 / 14						0	0		0	13.3	5	2	1	8	12.3
5 / 9							0		0	8.0	1	1	1	3	6.8
0 / 4											1	0	1	2	1.3
-5 / -1											0		0	0	-3.0
-10 / -6											0			0	-6.0

Caution: This summary reflects the typical distribution of temperature in a typical year. It does not reflect the typical moisture distribution. Because wet bulb temperatures are averaged, this summary understates the annual moisture load. For accurate moisture load data, see the long-term humidity summary and the ventilation and infiltration load pages in this manual.

KITZINGEN AAF, GERMANY

WMO No. 106590


Dry-Bulb Temperature Hours For An Average Year (Sheet 5 of 5)

Period of Record = 1965 to 1994


Annual Totals					
Temperature Range (°F)	Hour Group (LST)			Total Obs	M C W B (°F)
	01 To 08	09 To 16	17 To 00		
95 / 99		1	0	1	69.4
90 / 94		10	7	17	68.5
85 / 89		25	17	42	67.5
80 / 84		82	53	135	65.6
75 / 79	1	151	110	262	63.1
70 / 74	17	227	172	415	60.7
65 / 69	63	209	186	458	58.8
60 / 64	246	342	328	915	56.3
55 / 59	416	332	342	1090	52.7
50 / 54	443	291	325	1058	48.5
45 / 49	379	319	330	1027	43.6
40 / 44	312	242	273	826	39.7
35 / 39	424	335	354	1112	35.6
30 / 34	348	207	253	808	31.1
25 / 29	157	92	106	355	25.9
20 / 24	49	24	31	104	21.2
15 / 19	37	18	18	73	17.1
10 / 14	14	8	8	30	11.9
5 / 9	8	4	5	17	6.6
0 / 4	4	2	2	8	1.5
-5 / -1	3	1	1	4	-2.9
-10 / -6	1	0	0	1	-7.1

Caution: This summary reflects the typical distribution of temperature in a typical year. It does not reflect the typical moisture distribution. Because wet bulb temperatures are averaged, this summary understates the annual moisture load. For accurate moisture load data, see the long-term humidity summary and the ventilation and infiltration load pages in this manual.

Annual Summary of Temperatures



Long Term Humidity and Dry Bulb Temperature Summary




KITZINGEN AAF, GERMANY


WMO No. 106590

Long Term Dry Bulb Temperature and Humidity Summary

Week Ending	1.0% Temp (°F)	MCWB @ 1% Temp (°F)	Mean Max Temp (°F)	Mean Min Temp (°F)	99% Temp (°F)	1.0% HR (gr/lb)	MCDB @ 1% HR (°F)	Mean Max HR (gr/lb)	Mean Min HR (gr/lb)
7-Jan	52.0	48.9	36.6	29.2	3.0	48.3	50.6	29.4	22.2
14-Jan	52.0	48.0	36.1	27.5	-1.0	48.3	51.0	27.8	20.9
21-Jan	50.0	47.1	36.3	28.1	3.0	47.6	51.3	27.8	20.7
28-Jan	50.0	46.8	38.9	31.6	16.0	44.8	47.9	31.0	23.6
4-Feb	52.0	45.7	40.0	30.3	7.0	47.6	48.5	30.8	22.5
11-Feb	54.0	45.4	40.6	31.4	16.0	47.6	50.3	31.6	22.7
18-Feb	51.0	44.0	38.7	27.7	8.0	42.7	47.7	28.2	19.9
25-Feb	57.0	48.7	42.3	29.9	12.0	45.5	48.2	31.0	22.0
4-Mar	55.0	48.9	43.7	30.8	17.0	47.6	53.4	31.4	22.3
11-Mar	61.0	52.7	47.2	33.7	19.0	62.3	56.5	34.0	24.3
18-Mar	61.0	50.1	49.3	36.4	25.0	51.8	52.4	36.8	26.6
25-Mar	66.0	53.1	51.4	37.4	25.0	62.3	57.5	38.9	27.9
1-Apr	70.0	54.5	53.9	38.2	28.0	62.3	58.1	40.4	28.2
8-Apr	70.0	54.1	54.3	39.2	31.0	55.3	58.1	39.5	28.5
15-Apr	72.0	54.3	55.8	38.2	28.0	56.0	57.0	39.2	27.7
22-Apr	75.0	57.0	58.5	40.0	30.0	58.8	60.9	41.0	28.7
29-Apr	76.0	60.0	59.2	42.5	34.0	61.6	59.4	44.4	32.4
6-May	79.0	60.5	62.6	44.9	35.0	72.1	66.3	48.8	35.8
13-May	82.0	61.5	65.7	47.4	39.0	67.9	68.1	52.5	38.2
20-May	83.0	63.5	69.0	49.3	39.0	76.3	69.8	57.2	41.6
27-May	82.0	64.4	67.6	49.7	40.0	82.6	67.5	57.8	41.7
3-Jun	86.0	70.3	69.4	51.2	41.0	93.1	80.7	62.3	44.9
10-Jun	85.0	66.0	70.2	53.2	45.0	87.5	72.6	65.9	48.4
17-Jun	86.0	67.9	71.6	54.1	45.0	87.5	75.6	67.3	49.5
24-Jun	85.0	67.1	72.3	55.5	50.0	98.7	76.7	71.9	53.5
1-Jul	90.0	67.8	73.7	57.0	50.0	105.0	81.5	73.8	54.2
8-Jul	90.0	65.8	75.0	56.6	49.0	98.7	75.3	73.7	54.2
15-Jul	90.0	70.1	74.8	57.4	49.0	98.7	82.5	76.0	56.8
22-Jul	88.0	71.9	72.5	56.5	48.0	95.2	74.0	73.8	55.0
29-Jul	90.0	70.1	75.1	56.5	50.0	98.7	77.7	75.3	55.9
5-Aug	90.0	68.4	77.3	58.6	50.0	99.4	77.3	79.5	59.1
12-Aug	90.0	69.0	76.2	57.2	48.0	93.1	77.4	76.4	57.4
19-Aug	90.0	69.2	76.7	57.0	50.0	98.7	77.2	77.3	57.5
26-Aug	84.0	66.9	72.3	54.4	48.0	93.1	75.2	70.9	53.3
2-Sep	84.0	66.0	71.7	53.5	46.0	87.5	70.2	70.5	52.9
9-Sep	84.0	64.5	70.3	52.3	46.0	86.8	71.7	68.3	50.1
16-Sep	81.0	65.6	68.5	51.4	43.0	87.5	71.6	67.5	50.4
23-Sep	81.0	68.0	68.1	50.5	39.0	93.1	77.8	66.2	48.6
30-Sep	77.0	64.4	65.3	48.3	41.0	81.9	68.6	61.8	46.1
7-Oct	76.0	64.0	62.8	48.2	39.0	76.3	67.5	60.8	45.3
14-Oct	72.0	61.0	60.4	45.7	34.0	72.1	63.9	57.0	42.6
21-Oct	68.0	58.6	56.5	41.7	32.0	67.2	62.2	51.0	36.6
28-Oct	66.0	58.3	54.2	40.1	29.0	66.5	61.9	46.3	34.1
4-Nov	61.0	56.0	49.8	39.2	28.0	62.3	60.4	42.7	32.4
11-Nov	59.0	53.8	46.9	37.4	27.0	55.3	56.4	39.3	30.2
18-Nov	57.0	50.7	44.6	35.8	23.0	51.8	53.0	36.6	27.7
25-Nov	55.0	50.6	43.3	35.0	21.0	54.6	54.5	35.5	27.3
2-Dec	52.0	48.1	40.5	32.2	12.0	48.3	48.8	32.7	24.7
9-Dec	54.0	47.7	40.0	32.0	16.0	50.4	51.0	31.9	24.3
16-Dec	52.0	48.5	38.8	31.1	14.0	48.3	50.7	31.2	23.4
23-Dec	55.0	51.4	39.0	32.4	7.0	53.2	52.0	32.0	24.9
31-Dec	54.0	50.5	38.5	31.7	12.0	52.5	51.3	30.8	24.1




	Mean Cooling Degree Days (°F)	Mean Heating Degree Days (°F)
JAN	0	789
FEB	0	710
MAR	1	595
APR	7	413
MAY	35	214
JUN	76	114
JUL	102	76
AUG	96	82
SEP	30	168
OCT	4	382
NOV	0	590
DEC	0	735
ANN	350	4868



	Average Sensible Cooling Load	Average Sensible Heating Load	Average Latent Cooling Load	Average Latent Heating Load
	(Btu/cfm)	(Btu/cfm)	(Btu/cfm)	(Btu/cfm)
JAN	0	-22377	0	-1733
FEB	0	-20269	0	-1641
MAR	0	-17529	0	-1015
APR	11	-12606	0	-580
MAY	127	-7198	15	-96
JUN	416	-4242	136	-9
JUL	687	-3106	229	0
AUG	543	-3284	220	0
SEP	95	-5958	51	-3
OCT	5	-11901	1	-136
NOV	0	-17179	0	-655
DEC	0	-21023	0	-1339
ANN	1884	-146672	652	-7207

Average Annual Solar Radiation – Nearest Available Site
(Source: National Renewable Energy Laboratory, Golden CO, 1995)

No Solar Radiation
Data Available




Average Annual Solar Heat and Illumination – Nearest Available Site

(Source: National Renewable Energy Laboratory, Golden CO, 1995)

Wind Summary - December, January, and February


Labels of Percent Frequency on North Axis



Percent Calm = 24.17

Wind Summary - March, April, and May


Labels of Percent Frequency on North Axis



Percent Calm = 22.01

Wind Summary - June, July, and August


Labels of Percent Frequency on North Axis



Percent Calm = 27.01

Wind Summary - September, October, and November

Labels of Percent Frequency on North Axis



Percent Calm = 29.31