

LIMA/JORGE CHAVEZ PR

Latitude = 12.00 S

Longitude = 77.12 W

Period of Record = 1973 to 1996

WMO No. 846280

Elevation = 43 feet

Average Pressure = 29.83 inches Hg

Design Criteria Data

	Design Value	Mean Coincident (Average) Values			
		Wet Bulb Temperature (°F)	Humidity Ratio (gr/lb)	Wind Speed (mph)	Prevailing Direction (NSEW)
Dry Bulb Temperature (T)	(°F)				
Median of Extreme Highs	86	76	117	13.1	S
0.4% Occurrence	84	74	110	12.3	S
1.0% Occurrence	82	72	105	11.9	S
2.0% Occurrence	81	72	104	11.8	S
Mean Daily Range	9	-	-	-	-
97.5% Occurrence	59	57	67	5.0	S
99.0% Occurrence	57	56	65	3.4	S
99.6% Occurrence	57	56	65	3.4	S
Median of Extreme Lows	54	54	61	1.5	ENE
	Design Value	Mean Coincident (Average) Values			
		Dry Bulb Temperature (°F)	Humidity Ratio (gr/lb)	Wind Speed (mph)	Prevailing Direction (NSEW)
Wet Bulb Temperature (T_{wb})	(°F)				
Median of Extreme Highs	76	82	123	12.3	SSE
0.4% Occurrence	76	82	123	12.3	SSE
1.0% Occurrence	74	80	116	11.4	SSE
2.0% Occurrence	73	79	111	11.1	S
	Design Value	Mean Coincident (Average) Values			
		Dry Bulb Temperature (°F)	Vapor Pressure (in. Hg)	Wind Speed (mph)	Prevailing Direction (NSEW)
Humidity Ratio (HR)	(gr/lb)				
Median of Extreme Highs	125	80	0.83	11.4	SSE
0.4% Occurrence	125	80	0.83	11.5	SSE
1.0% Occurrence	118	79	0.78	11.1	SSE
2.0% Occurrence	111	77	0.74	10.2	SSE
Air Conditioning/ Humid Area Criteria	# of Hours	T ≥ 93°F	T ≥ 80°F	T _{wb} ≥ 73°F	T _{wb} ≥ 67°F
		0	234	215	2198

Other Site Data

Weather Region	Rain Rate 100 Year Recurrence (in./hr)	Basic Wind Speed 3 sec gust @ 33 ft 50 Year Recurrence (mph)	Ventilation Cooling Load Index (Ton-hr/cfm/yr) Base 75°F-RH 60% Latent + Sensible
9	N/A	N/A	2.9 + 0.3
Ground Water Temperature (°F) 50 Foot Depth *	Frost Depth 50 Year Recurrence (in.)	Ground Snow Load 50 Year Recurrence (lb/ft ²)	Average Annual Freeze-Thaw Cycles (#)
69.6	N/A	N/A	0


*Note: Temperatures at greater depths can be estimated by adding 1.5°F per 100 feet additional depth.

LIMA/JORGE CHAVEZ


PR

WMO No. 846280

Average Annual Climate




Long Term Psychrometric Summary



- 50% of all observations
- 80% of all observations
- 95% of all observations
- 97.5% of all observations
- 99% of all observations

Psychrometric Summary of Peak Design Values



99% Dry Bulb	(°F)	MCHR (gr/lb)	Enthalpy (btu/lb)	1.0% Humidity Ratio	(gr/lb)	MCDB (°F)	MCWB (°F)	MC Dewpt (°F)	Enthalpy (btu/lb)
	57	65.2	23.8		117.6	78.7	73.8	71.6	37.3

1.0% Dry Bulb	(°F)	MCHR (gr/lb)	MCWB (°F)	Enthalpy (btu/lb)
	82	106.6	72.8	36.4

LIMA/JORGE CHAVEZ

PR

WMO No. 846280

Dry-Bulb Temperature Hours For An Average Year (Sheet 1 of 5)

Period of Record = 1973 to 1996

Temperature Range (°F)	January					February					March				
	Hour Group (LST)			Total Obs	M C W B (°F)	Hour Group (LST)			Total Obs	M C W B (°F)	Hour Group (LST)			Total Obs	M C W B (°F)
	01 To 08	09 To 16	17 To 00			01 To 08	09 To 16	17 To 00			01 To 08	09 To 16	17 To 00		
90 / 94						0			0	77.5		1		1	77.3
85 / 89	0	5	0	5	76.3		8	0	8	75.6		10		10	75.5
80 / 84	0	45	4	50	72.2	0	60	6	66	72.4	1	52	7	60	72.5
75 / 79	15	137	47	199	70.0	18	117	60	195	70.5	23	125	54	202	70.4
70 / 74	116	54	161	331	67.6	128	36	142	305	68.2	109	54	152	314	67.9
65 / 69	107	6	36	148	65.7	74	3	16	93	66.2	104	6	32	142	65.9
60 / 64	11	0	0	11	63.0	4	0	0	4	63.7	12	1	3	16	63.1
55 / 59															
50 / 54															
45 / 49															

Caution: This summary reflects the typical distribution of temperature in a typical year. It does not reflect the typical moisture distribution. Because wet bulb temperatures are averaged, this summary understates the annual moisture load. For accurate moisture load data, see the long-term humidity summary and the ventilation and infiltration load pages in this manual.

LIMA/JORGE CHAVEZ

PR

WMO No. 846280

Dry-Bulb Temperature Hours For An Average Year (Sheet 2 of 5)

Period of Record = 1973 to 1996

Temperature Range (°F)	April					May					June				
	Hour Group (LST)			Total Obs	M C W B (°F)	Hour Group (LST)			Total Obs	M C W B (°F)	Hour Group (LST)			Total Obs	M C W B (°F)
	01 To 08	09 To 16	17 To 00			01 To 08	09 To 16	17 To 00			01 To 08	09 To 16	17 To 00		
90 / 94															
85 / 89		3		3	75.9		0		0	75.5					
80 / 84	0	17	2	19	73.3		9	0	9	72.8	0	3		3	72.0
75 / 79	13	84	21	118	69.7	9	23	12	44	69.5	5	9	7	21	69.6
70 / 74	25	106	86	217	66.7	6	100	21	127	65.4	6	35	7	49	65.0
65 / 69	121	27	105	253	64.9	54	83	102	239	63.6	19	90	41	151	62.2
60 / 64	80	4	26	109	62.4	162	32	110	304	61.2	165	98	172	435	59.9
55 / 59	1			1	58.2	17	1	3	21	57.8	43	4	13	60	57.2
50 / 54											2	0	0	2	52.9
45 / 49											0		0	0	

Caution: This summary reflects the typical distribution of temperature in a typical year. It does not reflect the typical moisture distribution. Because wet bulb temperatures are averaged, this summary understates the annual moisture load. For accurate moisture load data, see the long-term humidity summary and the ventilation and infiltration load pages in this manual.

LIMA/JORGE CHAVEZ

PR

WMO No. 846280

Dry-Bulb Temperature Hours For An Average Year (Sheet 3 of 5)

Period of Record = 1973 to 1996

Temperature Range (°F)	July					August					September				
	Hour Group (LST)			Total Obs	M C W B (°F)	Hour Group (LST)			Total Obs	M C W B (°F)	Hour Group (LST)			Total Obs	M C W B (°F)
	01 To 08	09 To 16	17 To 00			01 To 08	09 To 16	17 To 00			01 To 08	09 To 16	17 To 00		
90 / 94															
85 / 89			0	0	75.0										
80 / 84		0	0	0	69.0										
75 / 79		4	0	4	68.0	0	0	0	0	67.3					
70 / 74	3	18	5	26	64.8	0	11	1	12	63.2	0	15	0	15	63.0
65 / 69	9	69	20	99	61.6	5	60	13	78	61.3	0	76	9	85	61.1
60 / 64	156	147	183	486	59.1	138	168	189	494	59.0	147	142	198	486	59.2
55 / 59	79	10	39	128	56.8	104	10	45	159	56.9	93	7	33	133	57.0
50 / 54	1		0	1	52.6	1		0	1	52.2	0	0		0	51.0
45 / 49															

Caution: This summary reflects the typical distribution of temperature in a typical year. It does not reflect the typical moisture distribution. Because wet bulb temperatures are averaged, this summary understates the annual moisture load. For accurate moisture load data, see the long-term humidity summary and the ventilation and infiltration load pages in this manual.

LIMA/JORGE CHAVEZ

PR

WMO No. 846280

Dry-Bulb Temperature Hours For An Average Year (Sheet 4 of 5)

Period of Record = 1973 to 1996

Temperature Range (°F)	October					November					December				
	Hour Group (LST)			Total Obs	M C W B (°F)	Hour Group (LST)			Total Obs	M C W B (°F)	Hour Group (LST)			Total Obs	M C W B (°F)
	01 To 08	09 To 16	17 To 00			01 To 08	09 To 16	17 To 00			01 To 08	09 To 16	17 To 00		
90 / 94															
85 / 89															
80 / 84						0	0		0	71.3			0		74.4
75 / 79	0	1		1	67.2	0	16	1	17	67.4	3	95	15	113	68.5
70 / 74	0	49	2	51	63.7	5	123	19	147	64.6	42	117	99	258	66.2
65 / 69	7	121	36	164	61.8	55	82	107	244	62.9	131	23	111	265	64.4
60 / 64	204	76	199	479	59.7	174	19	111	304	60.7	71	2	23	96	61.8
55 / 59	37	1	11	49	57.1	7	0	1	8	57.3	1		0	1	58.3
50 / 54	0	0	0	0	52.7	0		0	0	53.0	0		0	0	
45 / 49						0			0						

Caution: This summary reflects the typical distribution of temperature in a typical year. It does not reflect the typical moisture distribution. Because wet bulb temperatures are averaged, this summary understates the annual moisture load. For accurate moisture load data, see the long-term humidity summary and the ventilation and infiltration load pages in this manual.

LIMA/JORGE CHAVEZ PR

WMO No. 846280


Dry-Bulb Temperature Hours For An Average Year (Sheet 5 of 5)

Period of Record = 1973 to 1996


Annual Totals					
Temperature Range (°F)	Hour Group (LST)			Total Obs	M C W B (°F)
	01 To 08	09 To 16	17 To 00		
90 / 94		1		1	77.3
85 / 89	0	26	0	26	75.7
80 / 84	1	189	19	210	72.5
75 / 79	84	592	211	887	69.9
70 / 74	423	713	668	1804	66.8
65 / 69	676	655	627	1958	63.6
60 / 64	1339	710	1242	3291	59.9
55 / 59	393	34	151	578	57.0
50 / 54	5	0	1	6	52.6
45 / 49	0		0	0	

Caution: This summary reflects the typical distribution of temperature in a typical year. It does not reflect the typical moisture distribution. Because wet bulb temperatures are averaged, this summary understates the annual moisture load. For accurate moisture load data, see the long-term humidity summary and the ventilation and infiltration load pages in this manual.

Annual Summary of Temperatures




Long Term Humidity and Dry Bulb Temperature Summary




LIMA/JORGE CHAVEZ**PR****WMO No. 846280****Long Term Dry Bulb Temperature and Humidity Summary**

Week Ending	1.0% Temp (°F)	MCWB @ 1% Temp (°F)	Mean Max Temp (°F)	Mean Min Temp (°F)	99% Temp (°F)	1.0% HR (gr/lb)	MCDB @ 1% HR (°F)	Mean Max HR (gr/lb)	Mean Min HR (gr/lb)
7-Jan	83.0	72.3	78.3	67.4	64.0	117.6	79.3	98.6	87.4
14-Jan	84.0	74.1	78.8	67.9	64.0	118.3	78.6	101.7	89.5
21-Jan	84.0	75.0	79.1	68.2	64.0	125.3	80.0	102.1	90.8
28-Jan	86.0	76.9	79.9	68.9	66.0	125.3	80.1	104.9	92.0
4-Feb	86.0	76.1	80.7	69.2	66.0	125.3	80.6	105.6	93.4
11-Feb	86.0	76.1	80.3	69.4	65.0	125.3	81.1	105.1	94.4
18-Feb	86.0	75.1	80.2	68.9	66.0	125.3	80.7	104.6	94.1
25-Feb	86.0	75.8	80.3	69.0	66.0	125.3	80.5	105.9	94.8
4-Mar	86.0	75.9	80.3	69.2	66.0	125.3	80.3	105.9	94.3
11-Mar	86.0	75.7	80.4	69.0	64.0	125.3	80.4	105.6	94.4
18-Mar	86.0	75.1	79.2	68.5	64.0	125.3	79.5	104.2	93.0
25-Mar	86.0	75.2	79.2	68.4	64.0	125.3	79.8	103.5	92.3
1-Apr	85.0	74.0	78.6	67.5	63.0	125.3	80.8	102.1	90.2
8-Apr	83.0	73.0	77.4	66.6	63.0	118.3	78.3	99.3	87.7
15-Apr	83.0	74.8	76.8	65.8	63.0	125.3	80.8	97.2	86.0
22-Apr	82.0	73.7	75.9	65.0	61.0	125.3	80.8	95.1	83.5
29-Apr	82.0	74.8	74.7	64.1	61.0	125.3	80.2	92.9	81.5
6-May	82.0	73.0	73.8	63.6	61.0	117.6	78.6	90.4	79.9
13-May	81.0	72.8	72.7	62.6	59.0	117.6	77.8	87.7	76.6
20-May	81.0	72.9	71.9	62.5	59.0	117.6	77.9	87.0	76.0
27-May	79.0	70.3	71.0	62.2	59.0	109.9	75.7	84.4	74.9
3-Jun	79.0	70.0	70.1	61.8	57.0	103.6	76.6	82.2	72.9
10-Jun	81.0	71.9	68.7	61.1	55.0	103.6	76.2	80.3	70.7
17-Jun	77.0	70.9	68.4	61.3	57.0	105.7	75.7	79.0	70.2
24-Jun	77.0	69.8	67.8	61.1	57.0	103.6	75.1	78.1	68.8
1-Jul	75.0	68.0	67.4	61.0	57.0	97.3	73.4	76.7	68.5
8-Jul	75.0	68.5	66.8	60.4	57.0	97.3	72.6	75.8	67.7
15-Jul	72.0	65.6	66.4	60.1	57.0	91.0	70.2	74.2	65.9
22-Jul	71.0	65.0	66.1	59.8	57.0	85.4	67.7	73.5	65.2
29-Jul	70.0	63.3	66.1	59.6	57.0	85.4	68.1	72.9	65.0
5-Aug	70.0	62.9	65.8	59.5	57.0	79.8	66.0	72.6	64.9
12-Aug	70.0	62.3	65.5	59.4	57.0	79.8	65.7	72.7	66.0
19-Aug	70.0	62.9	65.3	59.3	57.0	79.8	65.4	71.8	65.1
26-Aug	70.0	63.2	65.6	59.4	57.0	79.8	65.9	72.1	65.8
2-Sep	70.0	62.4	66.3	59.4	57.0	79.8	65.2	72.9	65.2
9-Sep	70.0	62.8	66.4	59.3	57.0	79.8	65.3	73.1	65.9
16-Sep	70.0	62.8	66.5	59.5	57.0	79.8	65.5	73.7	66.6
23-Sep	70.0	62.6	66.5	59.5	57.0	79.8	65.0	72.7	66.3
30-Sep	72.0	63.4	66.9	59.6	57.0	79.8	65.0	73.5	66.4
7-Oct	70.0	62.7	67.7	60.1	57.0	79.8	65.9	74.0	67.2
14-Oct	72.0	64.3	68.3	60.6	57.0	85.4	67.4	75.0	67.9
21-Oct	72.0	64.6	68.8	61.0	59.0	85.4	68.4	76.9	69.0
28-Oct	72.0	64.4	69.6	61.4	59.0	85.4	68.5	78.1	69.1
4-Nov	73.0	64.6	70.6	62.0	59.0	91.0	69.1	79.0	70.8
11-Nov	75.0	66.3	70.9	62.2	59.0	91.0	68.8	79.8	71.9
18-Nov	75.0	66.5	71.7	62.8	61.0	97.3	71.2	81.6	72.3
25-Nov	77.0	68.7	72.5	63.3	61.0	103.6	74.7	83.5	74.9
2-Dec	77.0	68.8	73.5	63.9	61.0	103.6	73.7	85.7	76.4
9-Dec	79.0	69.8	74.5	64.8	61.0	110.6	75.9	87.9	77.7
16-Dec	79.0	70.2	75.2	65.0	61.0	110.6	75.9	90.5	80.2
23-Dec	81.0	71.6	76.5	65.7	63.0	110.6	76.2	93.5	82.1
31-Dec	82.0	73.1	77.5	66.9	64.0	110.6	77.5	96.6	86.0



	Mean Cooling Degree Days (°F)	Mean Heating Degree Days (°F)
JAN	241	0
FEB	248	0
MAR	252	1
APR	155	6
MAY	77	29
JUN	34	59
JUL	15	89
AUG	8	101
SEP	9	91
OCT	24	55
NOV	65	23
DEC	156	5
ANN	1286	459

Average Ventilation and Infiltration Loads
(Outside Air vs. 75°F, 60% RH summer; 68°F, 30% RH winter)




■ Average Sensible Cooling Load	■ Average Sensible Heating Load
■ Average Latent Cooling (Drying) Load	■ Average Latent Heating (Humidifying) Load

	Average Sensible Cooling Load	Average Sensible Heating Load	Average Latent Cooling Load	Average Latent Heating Load
	(Btu/cfm)	(Btu/cfm)	(Btu/cfm)	(Btu/cfm)
JAN	720	-111	7294	0
FEB	928	-49	7944	0
MAR	879	-123	7896	0
APR	328	-710	4892	0
MAY	108	-2079	1826	0
JUN	43	-3358	571	0
JUL	4	-4437	177	0
AUG	0	-4848	24	0
SEP	0	-4488	17	0
OCT	0	-3272	109	0
NOV	13	-1881	738	0
DEC	217	-655	3580	0
ANN	3240	-26011	35068	0

Average Annual Solar Radiation – Nearest Available Site
(Source: National Renewable Energy Laboratory, Golden CO, 1995)

No Solar Radiation
Data Available





Average Annual Solar Heat and Illumination – Nearest Available Site

(Source: National Renewable Energy Laboratory, Golden CO, 1995)

Wind Summary - December, January, and February



Labels of Percent Frequency on North Axis



Percent Calm = 7.20

Wind Summary - March, April, and May


Labels of Percent Frequency on North Axis



Percent Calm = 15.17

Wind Summary - June, July, and August


Labels of Percent Frequency on North Axis



Percent Calm = 18.45

Wind Summary - September, October, and November

Labels of Percent Frequency on North Axis



Percent Calm = 9.47