

NINOY AQUINO PH

Latitude = 14.52 N

WMO No. 984290

Longitude = 121.00 E

Elevation = 69 feet

Period of Record = 1973 to 1996

Average Pressure = 29.72 inches Hg

Design Criteria Data

	Design Value	Mean Coincident (Average) Values			
		Wet Bulb Temperature (oF)	Humidity Ratio (gr/lb)	Wind Speed (mph)	Prevailing Direction (NSEW)
Dry Bulb Temperature (T)	(oF)				
Median of Extreme Highs	98	80	127	15.8	E
0.4% Occurrence	95	80	129	16.3	E
1.0% Occurrence	93	79	128	16.2	E
2.0% Occurrence	93	79	128	16.2	E
Mean Daily Range	14	-	-	-	-
97.5% Occurrence	72	70	106	3.1	E
99.0% Occurrence	70	67	97	2.1	E
99.6% Occurrence	68	66	93	2.0	E
Median of Extreme Lows	64	62	81	0.9	ENE
	Design Value	Mean Coincident (Average) Values			
		Dry Bulb Temperature (oF)	Humidity Ratio (gr/lb)	Wind Speed (mph)	Prevailing Direction (NSEW)
Wet Bulb Temperature (Twb)	(oF)				
Median of Extreme Highs	86	91	176	12.4	E
0.4% Occurrence	83	90	155	13.5	W
1.0% Occurrence	82	89	151	13.1	W
2.0% Occurrence	81	88	146	12.8	W
	Design Value	Mean Coincident (Average) Values			
		Dry Bulb Temperature (oF)	Vapor Pressure (in. Hg)	Wind Speed (mph)	Prevailing Direction (NSEW)
Humidity Ratio (HR)	(gr/lb)				
Median of Extreme Highs	190	81	0.81	10.2	ESE
0.4% Occurrence	162	87	1.07	8.8	W
1.0% Occurrence	160	88	1.05	12.4	W
2.0% Occurrence	151	86	0.99	11.6	W
Air Conditioning/ Humid Area Criteria	# of Hours	T ≥ 93oF	T ≥ 80oF	Twb ≥ 73oF	Twb ≥ 67oF
		171	4755	6919	8384


Other Site Data

Weather Region	Rain Rate 100 Year Recurrence (in./hr)	Basic Wind Speed 3 sec gust @ 33 ft 50 Year Recurrence (mph)	Ventilation Cooling Load Index (Ton-hr/cfm/yr) Base 75oF-RH 60% Latent + Sensible
10	N/A	N/A	19.4 + 5.0
Ground Water Temperature (oF) 50 Foot Depth *	Frost Depth 50 Year Recurrence (in.)	Ground Snow Load 50 Year Recurrence (lb/ft2)	Average Annual Freeze-Thaw Cycles (#)
83.6	N/A	N/A	0

*Note: Temperatures at greater depths can be estimated by adding 1.5oF per 100 feet additional depth.

NINOY AQUINO PH

WMO No. 984290




No Precipitation Data Available

NINOY AQUINO PH


WMO No. 984290

Long Term Psychrometric Summary



- 50% of all observations
- 80% of all observations
- 95% of all observations
- 97.5% of all observations
- 99% of all observations

Psychrometric Summary of Peak Design Values



99% Dry Bulb	(°F)	MCHR (gr/lb)	Enthalpy (btu/lb)	1.0% Humidity Ratio	(gr/lb)	MCDB (°F)	MCWB (°F)	MC Dewpt (°F)	Enthalpy (btu/lb)
	70	97.1	31.9		159.6	87.6	82.3	80.6	46.1

1.0% Dry Bulb	(°F)	MCHR (gr/lb)	MCWB (°F)	Enthalpy (btu/lb)
	93	126.6	78.9	42.3

NINOY AQUINO PH

WMO No. 984290

Dry-Bulb Temperature Hours For An Average Year (Sheet 1 of 5)

Period of Record = 1973 to 1996

January						February					March				
Temperature Range (oF)	Hour Group (LST)			Total Obs	M C W B (oF)	Hour Group (LST)			Total Obs	M C W B (oF)	Hour Group (LST)			Total Obs	M C W B (oF)
	01 To 08	09 To 16	17 To 00			01 To 08	09 To 16	17 To 00			01 To 08	09 To 16	17 To 00		
100 / 104															
95 / 99						0 0					77.2				
90 / 94	8 0 8 76.8					23 1 24					76.4				
85 / 89	0	62	7	69	75.9	0	80	16	96	75.4	1	90	34	125	75.8
80 / 84	2	135	71	209	74.1	4	97	79	181	73.8	27	63	118	208	74.3
75 / 79	98	41	141	280	72.0	107	22	113	242	71.7	159	8	83	250	72.1
70 / 74	127	2	28	158	69.2	103	1	15	119	69.0	57		0 5		62 69.2
65 / 69	18	0	0	18	65.6	10	0	0	10	65.9	4		0	0	4 65.8
60 / 64	3			3	61.8	0		0 0		0 62.3		0			0 62.2
55 / 59								0	0	0					

Caution: This summary reflects the typical distribution of temperature in a typical year. It does not reflect the typical moisture distribution. Because wet bulb temperatures are averaged, this summary understates the annual moisture load. For accurate moisture load data, see the long-term humidity summary and the ventilation and infiltration load pages in this manual.

NINOY AQUINO PH

WMO No. 984290

Dry-Bulb Temperature Hours For An Average Year (Sheet 2 of 5)

Period of Record = 1973 to 1996

Temperature Range (oF)	April					May					June				
	Hour Group (LST)			Total Obs	M C W B (oF)	Hour Group (LST)			Total Obs	M C W B (oF)	Hour Group (LST)			Total Obs	M C W B (oF)
	01 To 08	09 To 16	17 To 00			01 To 08	09 To 16	17 To 00			01 To 08	09 To 16	17 To 00		
100 / 104															
95 / 99		19	1	20	78.6		28	1	29	80.3	0	7	0	7	80.7
90 / 94	0	134	25	159	78.0	1	122	26	149	79.2	0	78	11	89	79.9
85 / 89	8	64	54	126	77.0	15	67	66	148	78.2	7	88	39	135	78.8
80 / 84	84		21	134	75.2	113	25	124	262	76.3	79	52	128	258	77.0
75 / 79	134		2	26	73.2	114	5	30	149	74.3	142	13	57	213	74.9
70 / 74	14		0	0	70.2	6	1	1	8	71.3	12	1	5	18	70.1
65 / 69		0		0	67.0						0		0	0	67.0
60 / 64															
55 / 59															

Caution: This summary reflects the typical distribution of temperature in a typical year. It does not reflect the typical moisture distribution. Because wet bulb temperatures are averaged, this summary understates the annual moisture load. For accurate moisture load data, see the long-term humidity summary and the ventilation and infiltration load pages in this manual.

NINOY AQUINO PH

WMO No. 984290

Dry-Bulb Temperature Hours For An Average Year (Sheet 3 of 5)

Period of Record = 1973 to 1996

Temperature Range (oF)	July					August					September				
	Hour Group (LST)			Total Obs	M C W B (oF)	Hour Group (LST)			Total Obs	M C W B (oF)	Hour Group (LST)			Total Obs	M C W B (oF)
	01 To 08	09 To 16	17 To 00			01 To 08	09 To 16	17 To 00			01 To 08	09 To 16	17 To 00		
100 / 104															
95 / 99		1 0		1	80.7	0	0		0	82.5		0	0	0	79.6
90 / 94		41	4	45	79.8	0	21 1		22	80.3	0	25	1	26	79.9
85 / 89	3	103	28	134	78.9	1	96	19	116	79.1	0	99	17	116	79.2
80 / 84	56	81	122	259	77.1	43	97	110	249	77.3	40		96	123	77.4
75 / 79	177	22	90	290	74.9	186	34	114	334	75.0	188		19	97	75.1
70 / 74	12	1	3	16	71.3	18	1	4	23	71.2	12	1	2	15	71.8
65 / 69						0	0	0	0	67.3	0	0	0	0	
60 / 64											0	0	0	0	58.3
55 / 59											0		0	0	55.5

Caution: This summary reflects the typical distribution of temperature in a typical year. It does not reflect the typical moisture distribution. Because wet bulb temperatures are averaged, this summary understates the annual moisture load. For accurate moisture load data, see the long-term humidity summary and the ventilation and infiltration load pages in this manual.

NINOY AQUINO PH

WMO No. 984290

Dry-Bulb Temperature Hours For An Average Year (Sheet 4 of 5)

Period of Record = 1973 to 1996

Temperature Range (oF)	October					November					December				
	Hour Group (LST)			Total Obs	M C W B (oF)	Hour Group (LST)			Total Obs	M C W B (oF)	Hour Group (LST)			Total Obs	M C W B (oF)
	01 To 08	09 To 16	17 To 00			01 To 08	09 To 16	17 To 00			01 To 08	09 To 16	17 To 00		
100 / 104		0		0	82.3										
95 / 99		0		0	79.0		0		0	79.2					
90 / 94	0	26	1	27	79.4		26	1	27	78.8		9	0	9	77.6
85 / 89	0	102	18	120	78.7	0	88	12	100	77.6	0	67	5	72	76.6
80 / 84	35	93	127	255	76.9	19	102	106	227	76.0	5	132	73	210	74.8
75 / 79	190		26	97	74.8	176		22	116	73.9	126	36	147	310	72.8
70 / 74	22		1	5	71.0	45		2	4	70.8	105	4	22	130	69.9
65 / 69		1	0		66.7	0		0	0	66.7	11		1	12	66.1
60 / 64		0			64.0						1			1	62.4
55 / 59															

Caution: This summary reflects the typical distribution of temperature in a typical year. It does not reflect the typical moisture distribution. Because wet bulb temperatures are averaged, this summary understates the annual moisture load. For accurate moisture load data, see the long-term humidity summary and the ventilation and infiltration load pages in this manual.

NINOY AQUINO PH

WMO No. 984290


Dry-Bulb Temperature Hours For An Average Year (Sheet 5 of 5)

Period of Record = 1973 to 1996


Annual Totals					
Temperature Range (oF)	Hour Group (LST)			Total Obs	M C W B (oF)
	01 To 08	09 To 16	17 To 00		
100 / 104		0		0	82.3
95 / 99	0	58	2	60	79.7
90 / 94	1	600	80	681	78.6
85 / 89	35	1003	319	1357	77.7
80 / 84	504	994	1312	2810	76.0
75 / 79	1795	249	1110	3154	73.8
70 / 74	537	15	95	647	69.8
65 / 69	44	1	2	47	65.9
60 / 64	4	0	0	4	61.9
55 / 59	0	0	0	0	55.5

Caution: This summary reflects the typical distribution of temperature in a typical year. It does not reflect the typical moisture distribution. Because wet bulb temperatures are averaged, this summary understates the annual moisture load. For accurate moisture load data, see the long-term humidity summary and the ventilation and infiltration load pages in this manual.

Annual Summary of Temperatures




Long Term Humidity and Dry Bulb Temperature Summary




NINOY AQUINO PH**WMO No. 984290****Long Term Dry Bulb Temperature and Humidity Summary**

Week Ending	1.0% Temp (°F)	MCWB @ 1% Temp (°F)	Mean Max Temp (°F)	Mean Min Temp (°F)	99% Temp (°F)	1.0% HR (gr/lb)	MCDB @ 1% HR (°F)	Mean Max HR (gr/lb)	Mean Min HR (gr/lb)
7-Jan	90.0	77.4	85.7	71.9	68.0	141.4	86.4	127.3	99.1
14-Jan	88.0	76.3	85.5	71.4	68.0	141.4	83.4	127.6	98.6
21-Jan	90.0	77.2	85.8	70.6	66.0	141.4	83.1	126.4	95.7
28-Jan	90.0	75.4	86.0	71.2	66.0	141.4	84.7	125.3	97.0
4-Feb	90.0	77.1	86.3	71.2	68.0	135.8	82.0	124.8	96.1
11-Feb	90.0	76.1	86.9	71.4	68.0	140.7	86.0	124.3	94.6
18-Feb	90.0	76.8	87.8	72.2	68.0	139.3	86.5	127.9	97.7
25-Feb	91.0	76.7	88.3	72.0	69.0	136.5	86.5	127.7	97.4
4-Mar	91.0	76.8	88.5	72.5	70.0	141.4	85.9	127.4	97.1
11-Mar	92.0	76.6	89.1	72.8	68.0	133.7	84.5	126.8	97.6
18-Mar	93.0	76.8	90.2	73.4	70.0	141.4	85.7	132.9	99.3
25-Mar	93.0	77.0	90.6	74.2	72.0	144.2	86.5	133.5	101.5
1-Apr	93.0	77.2	91.3	74.6	72.0	144.9	89.3	133.8	103.0
8-Apr	95.0	77.9	92.0	75.4	73.0	151.2	88.0	135.8	105.3
15-Apr	95.0	78.3	92.6	76.0	73.0	151.2	87.8	139.8	107.0
22-Apr	95.0	78.7	92.9	76.5	73.0	159.6	90.9	142.5	108.5
29-Apr	95.0	78.7	93.2	77.1	73.0	157.5	91.3	140.4	108.5
6-May	96.0	80.9	93.7	77.6	75.0	160.3	91.0	144.7	112.7
13-May	97.0	80.4	94.1	77.8	75.0	160.3	93.1	147.3	114.4
20-May	95.0	80.4	92.1	77.6	73.0	160.3	90.0	149.0	117.4
27-May	96.0	81.7	91.6	77.4	73.0	161.0	89.5	150.3	117.0
3-Jun	95.0	80.6	90.7	77.1	73.0	170.8	90.5	148.6	117.5
10-Jun	95.0	80.1	91.2	76.9	72.0	160.3	89.6	148.3	116.3
17-Jun	95.0	80.6	90.1	76.9	70.0	160.3	89.1	150.7	118.9
24-Jun	93.0	80.8	88.7	76.2	72.0	160.3	89.1	151.7	120.7
1-Jul	92.0	80.4	88.8	76.3	73.0	160.3	87.7	147.7	119.9
8-Jul	93.0	80.2	88.7	76.3	73.0	160.3	87.2	150.2	119.4
15-Jul	91.0	79.5	88.3	75.9	73.0	160.3	87.8	148.1	119.1
22-Jul	91.0	79.7	87.6	75.8	73.0	159.6	86.6	148.4	119.2
29-Jul	91.0	80.0	87.4	75.9	73.0	160.3	86.3	147.3	121.3
5-Aug	90.0	79.9	87.2	75.7	73.0	161.0	85.8	149.0	118.8
12-Aug	90.0	80.5	86.3	75.3	72.0	160.3	87.8	148.4	119.3
19-Aug	90.0	80.2	86.2	75.4	73.0	154.7	87.8	149.5	120.4
26-Aug	90.0	80.0	86.7	75.6	73.0	160.3	87.1	152.1	121.1
2-Sep	91.0	80.5	87.5	75.6	73.0	160.3	87.0	150.5	119.9
9-Sep	91.0	79.5	87.6	75.6	73.0	159.6	87.3	147.8	120.2
16-Sep	90.0	79.4	87.2	75.8	73.0	161.0	84.5	149.0	121.8
23-Sep	90.0	79.9	87.3	75.4	73.0	160.3	84.3	151.0	122.1
30-Sep	90.0	80.2	88.1	75.7	73.0	161.0	85.5	154.8	121.6
7-Oct	91.0	80.3	87.6	75.5	72.0	160.3	86.1	148.1	119.7
14-Oct	91.0	79.6	87.6	75.2	72.0	160.3	85.2	148.1	118.8
21-Oct	90.0	79.9	87.5	75.2	72.0	160.3	85.0	145.3	118.6
28-Oct	91.0	79.5	87.5	75.1	72.0	159.6	84.7	144.6	116.6
4-Nov	91.0	80.4	87.1	74.7	72.0	160.3	85.3	142.1	116.3
11-Nov	91.0	79.1	87.5	74.5	72.0	157.5	84.7	142.3	112.6
18-Nov	91.0	78.4	87.7	74.4	72.0	150.5	85.9	142.3	111.4
25-Nov	91.0	78.3	87.3	74.2	72.0	152.6	79.0	139.3	110.5
2-Dec	90.0	78.8	86.4	73.5	72.0	150.5	84.0	136.4	107.5
9-Dec	90.0	77.1	86.1	72.8	70.0	150.5	83.7	134.0	105.9
16-Dec	88.0	76.8	85.9	72.2	68.0	141.4	83.1	130.9	103.5
23-Dec	89.0	78.7	85.8	72.0	68.0	142.1	83.6	131.2	101.6
31-Dec	90.0	77.2	85.4	71.7	68.0	141.4	84.3	128.3	100.6



	Mean Cooling Degree Days (°F)	Mean Heating Degree Days (°F)
JAN	407	0
FEB	404	0
MAR	511	0
APR	571	0
MAY	604	0
JUN	532	0
JUL	509	0
AUG	485	0
SEP	478	0
OCT	489	0
NOV	456	0
DEC	420	0
ANN	5867	0




	Average Sensible Cooling Load	Average Sensible Heating Load	Average Latent Cooling Load	Average Latent Heating Load
	(Btu/cfm)	(Btu/cfm)	(Btu/cfm)	(Btu/cfm)
JAN	3153	-22	13813	0
FEB	3564	-7	12419	0
MAR	5421	-2	15254	0
APR	7114	0	18393	0
MAY	7645	0	22634	0
JUN	6069	0	22886	0
JUL	5229	0	23320	0
AUG	4616	0	23173	0
SEP	4688	-3	22782	0
OCT	4746	0	22573	0
NOV	4182	0	19560	0
DEC	3296	-8	16379	0
ANN	59723	-42	233186	0

Average Annual Solar Radiation – Nearest Available Site

(Source: National Renewable Energy Laboratory, Golden CO, 1995)

No Solar Radiation
Data Available




Average Annual Solar Heat and Illumination – Nearest Available Site

(Source: National Renewable Energy Laboratory, Golden CO, 1995)

Wind Summary - December, January, and February


Labels of Percent Frequency on North Axis



Percent Calm = 31.75

Wind Summary - March, April, and May


Labels of Percent Frequency on North Axis



Percent Calm = 22.08

Wind Summary - June, July, and August


Labels of Percent Frequency on North Axis



Percent Calm = 32.59

Wind Summary - September, October, and November

Labels of Percent Frequency on North Axis



Percent Calm = 38.00