

SYDNEY AU

Latitude = 33.90 S

Longitude = 151.18 E

Period of Record = 1973 to 1996

WMO No. 947670

Elevation = 10 feet

Average Pressure = 29.97 inches Hg

Design Criteria Data

	Design Value	Mean Coincident (Average) Values			
		Wet Bulb Temperature (°F)	Humidity Ratio (gr/lb)	Wind Speed (mph)	Prevailing Direction (NSEW)
Dry Bulb Temperature (T)	(°F)				
Median of Extreme Highs	104	70	56	16.4	W
0.4% Occurrence	91	67	65	11.9	WNW
1.0% Occurrence	86	68	75	11.3	NE
2.0% Occurrence	82	68	79	11.4	NE
Mean Daily Range	14	-	-	-	-
97.5% Occurrence	46	43	35	3.7	NW
99.0% Occurrence	43	40	32	3.1	NW
99.6% Occurrence	41	39	30	3.7	NW
Median of Extreme Lows	37	35	27	3.2	NW
	Design Value	Mean Coincident (Average) Values			
		Dry Bulb Temperature (°F)	Humidity Ratio (gr/lb)	Wind Speed (mph)	Prevailing Direction (NSEW)
Wet Bulb Temperature (T_{wb})	(°F)				
Median of Extreme Highs	76	87	114	8.1	NE
0.4% Occurrence	73	80	108	9.0	NNE
1.0% Occurrence	72	79	106	8.8	NNE
2.0% Occurrence	71	77	102	8.9	NNE
	Design Value	Mean Coincident (Average) Values			
		Dry Bulb Temperature (°F)	Vapor Pressure (in. Hg)	Wind Speed (mph)	Prevailing Direction (NSEW)
Humidity Ratio (HR)	(gr/lb)				
Median of Extreme Highs	125	80	0.83	5.8	NE
0.4% Occurrence	116	76	0.78	7.2	S
1.0% Occurrence	110	75	0.74	7.5	NNE
2.0% Occurrence	106	75	0.71	8.7	S
Air Conditioning/ Humid Area Criteria	# of Hours	T ≥ 93°F	T ≥ 80°F	T _{wb} ≥ 73°F	T _{wb} ≥ 67°F
		25	321	73	1111


Other Site Data

Weather Region	Rain Rate 100 Year Recurrence (in./hr)	Basic Wind Speed 3 sec gust @ 33 ft 50 Year Recurrence (mph)	Ventilation Cooling Load Index (Ton-hr/cfm/yr) Base 75°F-RH 60% Latent + Sensible
9	N/A	N/A	0.8 + 0.3
Ground Water Temperature (°F) 50 Foot Depth *	Frost Depth 50 Year Recurrence (in.)	Ground Snow Load 50 Year Recurrence (lb/ft ²)	Average Annual Freeze-Thaw Cycles (#)
66.5	N/A	N/A	0

*Note: Temperatures at greater depths can be estimated by adding 1.5°F per 100 feet additional depth.

SYDNEY AU

WMO No. 947670




No Precipitation Data Available

SYDNEY AU

WMO No. 947670

Long Term Psychrometric Summary




- 50% of all observations
- 80% of all observations
- 95% of all observations
- 97.5% of all observations
- 99% of all observations

SYDNEY AU

WMO No. 947670

Psychrometric Summary of Peak Design Values



	(°F)	MCHR (gr/lb)	Enthalpy (btu/lb)	1.0% Humidity Ratio	(gr/lb)	MCDB (°F)	MCWB (°F)	MC Dewpt (°F)	Enthalpy (btu/lb)
99% Dry Bulb	43	31.8	15.2		109.9	75.3	71.4	69.8	35.3

	(°F)	MCHR (gr/lb)	MCWB (°F)	Enthalpy (btu/lb)
1.0% Dry Bulb	86	75.3	67.9	32.5

SYDNEY AU

WMO No. 947670

Dry-Bulb Temperature Hours For An Average Year (Sheet 1 of 5)

Period of Record = 1973 to 1996

Temperature Range (°F)	January					February					March				
	Hour Group (LST)			Total Obs	M C W B (°F)	Hour Group (LST)			Total Obs	M C W B (°F)	Hour Group (LST)			Total Obs	M C W B (°F)
	01 To 08	09 To 16	17 To 00			01 To 08	09 To 16	17 To 00			01 To 08	09 To 16	17 To 00		
105 / 109		0		0	79.0		0		0	72.3					
100 / 104		1		1	70.1		1	0	1	70.8		0		0	67.3
95 / 99		2	0	2	70.2		3	1	4	72.9		1		1	66.7
90 / 94	0	6	1	7	70.6	0	4	1	5	70.7		2	0	2	68.0
85 / 89	1	10	1	12	70.9	0	6	2	9	71.8		4	0	4	68.0
80 / 84	2	42	11	55	70.0	1	32	8	41	70.0	0	25	2	27	67.9
75 / 79	14	72	55	142	68.5	12	70	45	127	68.3	2	66	30	98	67.2
70 / 74	101	87	122	310	66.1	96	78	118	292	66.1	56	99	111	266	65.4
65 / 69	95	26	50	171	63.1	80	27	41	148	63.0	93	41	83	218	62.5
60 / 64	30	3	7	40	59.8	31	4	8	43	59.4	75	10	21	105	59.3
55 / 59	4	0	0	4	55.5	4	0		4	54.9	21	0	1	22	54.2
50 / 54		0		0		0			0	49.0	1		0	1	49.1
45 / 49											0			0	45.0
40 / 44															
35 / 39															
30 / 34															

Caution: This summary reflects the typical distribution of temperature in a typical year. It does not reflect the typical moisture distribution. Because wet bulb temperatures are averaged, this summary understates the annual moisture load. For accurate moisture load data, see the long-term humidity summary and the ventilation and infiltration load pages in this manual.

SYDNEY AU

WMO No. 947670

Dry-Bulb Temperature Hours For An Average Year (Sheet 2 of 5)

Period of Record = 1973 to 1996

Temperature Range (°F)	April					May					June				
	Hour Group (LST)			Total Obs	M C W B (°F)	Hour Group (LST)			Total Obs	M C W B (°F)	Hour Group (LST)			Total Obs	M C W B (°F)
	01 To 08	09 To 16	17 To 00			01 To 08	09 To 16	17 To 00			01 To 08	09 To 16	17 To 00		
105 / 109															
100 / 104															
95 / 99		0		0	65.7										
90 / 94		1		1	65.6										
85 / 89		2	0	2	63.7	0			0						
80 / 84	0	7	1	8	64.4	0	1		1	62.8		0		0	63.0
75 / 79	0	32	4	36	64.0	0	9	1	10	61.6		1		1	58.7
70 / 74	10	78	48	137	63.1	0	33	9	42	61.0		5	0	5	58.9
65 / 69	37	69	85	192	61.2	9	76	40	124	60.0	1	26	7	34	56.8
60 / 64	90	45	82	217	58.3	52	88	110	251	57.6	11	90	37	139	54.7
55 / 59	74	5	17	97	53.7	88	34	69	192	53.8	47	81	113	242	52.1
50 / 54	25	0	2	27	49.2	71	7	17	95	49.2	72	29	66	167	48.0
45 / 49	3			3	43.5	26	1	1	28	44.8	86	7	16	109	43.6
40 / 44						1	0	0	1	39.7	20	0	1	21	39.7
35 / 39						0	0	0	0	37.8	2	0		2	36.0
30 / 34							0	0	0		0			0	

Caution: This summary reflects the typical distribution of temperature in a typical year. It does not reflect the typical moisture distribution. Because wet bulb temperatures are averaged, this summary understates the annual moisture load. For accurate moisture load data, see the long-term humidity summary and the ventilation and infiltration load pages in this manual.

SYDNEY AU

WMO No. 947670

Dry-Bulb Temperature Hours For An Average Year (Sheet 3 of 5)

Period of Record = 1973 to 1996

Temperature Range (°F)	July					August					September				
	Hour Group (LST)			Total Obs	M C W B (°F)	Hour Group (LST)			Total Obs	M C W B (°F)	Hour Group (LST)			Total Obs	M C W B (°F)
	01 To 08	09 To 16	17 To 00			01 To 08	09 To 16	17 To 00			01 To 08	09 To 16	17 To 00		
105 / 109															
100 / 104															
95 / 99												0		0	
90 / 94												1	0	1	59.6
85 / 89							0		0	63.4		2	0	2	60.0
80 / 84							2	0	2	58.8		5	1	7	59.6
75 / 79		1		1	60.4		4	1	6	58.0	1	15	4	20	58.3
70 / 74		6	0	6	56.0	1	12	5	18	55.9	2	32	12	46	56.8
65 / 69	0	18	2	20	54.2	2	33	8	43	54.1	5	49	24	79	55.7
60 / 64	5	72	25	102	52.6	7	82	42	131	52.5	27	84	72	183	54.4
55 / 59	25	93	96	215	50.4	48	79	105	232	50.8	75	46	97	218	51.5
50 / 54	68	39	95	202	47.1	70	31	71	172	46.9	88	6	27	121	47.9
45 / 49	104	18	28	150	43.2	90	4	16	110	43.0	39	0	2	41	43.5
40 / 44	38	2	1	41	39.7	28	0	0	28	40.0	3			3	40.0
35 / 39	7	0	0	7	36.2	2			2	36.2					
30 / 34	0	0		0	32.3	0			0						

Caution: This summary reflects the typical distribution of temperature in a typical year. It does not reflect the typical moisture distribution. Because wet bulb temperatures are averaged, this summary understates the annual moisture load. For accurate moisture load data, see the long-term humidity summary and the ventilation and infiltration load pages in this manual.

SYDNEY AU

WMO No. 947670

Dry-Bulb Temperature Hours For An Average Year (Sheet 4 of 5)

Period of Record = 1973 to 1996

Temperature Range (°F)	October					November					December				
	Hour Group (LST)			Total Obs	M C W B (°F)	Hour Group (LST)			Total Obs	M C W B (°F)	Hour Group (LST)			Total Obs	M C W B (°F)
	01 To 08	09 To 16	17 To 00			01 To 08	09 To 16	17 To 00			01 To 08	09 To 16	17 To 00		
105 / 109						0			0	70.0			0		0 68.5
100 / 104		0		0	63.0	1	0		1	68.4		1		1	67.8
95 / 99	0	1	0	1	63.0	2	0		2	68.2	0	3	0	3	68.2
90 / 94	0	4	1	5	62.4	0	3	0	3	65.2	0	5	1	7	67.6
85 / 89	0	4	0	4	62.4	0	5	1	6	65.8	0	7	1	8	67.7
80 / 84	0	9	3	12	62.0	1	13	3	17	65.4	1	28	8	37	67.7
75 / 79	1	26	8	34	60.4	2	37	11	50	64.0	7	66	30	103	66.4
70 / 74	6	61	22	89	59.6	19	76	47	142	62.6	64	81	101	246	64.8
65 / 69	22	64	54	140	58.8	47	60	83	190	60.6	90	43	72	206	61.8
60 / 64	85	63	108	256	56.5	104	36	74	215	57.5	68	13	33	114	58.3
55 / 59	89	16	47	153	52.7	53	7	19	79	53.4	17	0	1	18	53.8
50 / 54	40	1	4	46	48.7	13	1	1	15	49.3	1			1	50.8
45 / 49	5	0	0	5	44.5	1			1	45.7					
40 / 44															
35 / 39															
30 / 34															

Caution: This summary reflects the typical distribution of temperature in a typical year. It does not reflect the typical moisture distribution. Because wet bulb temperatures are averaged, this summary understates the annual moisture load. For accurate moisture load data, see the long-term humidity summary and the ventilation and infiltration load pages in this manual.

WMO No. 947670


Period of Record = 1973 to 1996

Caution: This summary reflects the typical distribution of temperature in a typical year. It does not reflect the typical moisture distribution. Because wet bulb temperatures are averaged, this summary understates the annual moisture load. For accurate moisture load data, see the long-term humidity summary and the ventilation and infiltration load pages in this manual.

SYDNEY AU

WMO No. 947670


Annual Summary of Temperatures



SYDNEY AU


WMO No. 947670

Long Term Humidity and Dry Bulb Temperature Summary




SYDNEY AU**WMO No. 947670****Long Term Dry Bulb Temperature and Humidity Summary**

Week Ending	1.0% Temp (°F)	MCWB @ 1% Temp (°F)	Mean Max Temp (°F)	Mean Min Temp (°F)	99% Temp (°F)	1.0% HR (gr/lb)	MCDB @ 1% HR (°F)	Mean Max HR (gr/lb)	Mean Min HR (gr/lb)
7-Jan	91.0	72.8	78.0	66.6	60.0	114.1	76.8	96.5	73.6
14-Jan	91.0	67.8	78.9	66.6	61.0	114.1	77.7	93.6	71.4
21-Jan	91.0	73.2	79.0	67.5	61.0	117.6	77.2	97.6	75.9
28-Jan	91.0	69.4	77.9	67.3	63.0	124.6	80.4	96.7	75.5
4-Feb	97.0	72.4	80.4	67.7	61.0	117.6	77.1	98.2	75.8
11-Feb	92.0	69.0	78.9	67.2	61.0	117.6	75.6	97.4	75.6
18-Feb	86.0	72.5	78.1	67.1	60.0	117.6	77.6	96.1	76.8
25-Feb	84.0	69.7	77.0	66.6	61.0	111.3	77.0	95.4	76.3
4-Mar	87.0	69.0	77.3	66.2	61.0	111.3	74.8	94.0	73.1
11-Mar	86.0	69.8	76.6	65.1	57.0	116.9	74.7	92.7	73.1
18-Mar	84.0	67.5	76.1	63.6	56.0	109.9	74.0	88.7	67.6
25-Mar	84.0	66.9	75.7	64.0	59.0	109.9	74.0	89.7	69.2
1-Apr	86.0	67.5	75.1	62.2	55.0	102.2	72.5	84.9	63.6
8-Apr	88.0	66.3	74.7	61.1	54.0	102.9	71.7	81.9	61.3
15-Apr	81.0	67.1	71.7	59.0	52.0	102.9	72.1	77.7	58.3
22-Apr	79.0	62.3	71.5	57.2	50.0	91.0	68.0	73.2	54.1
29-Apr	81.0	62.3	71.3	56.5	50.0	90.3	68.1	70.2	51.5
6-May	79.0	60.5	69.7	55.9	50.0	93.1	67.8	72.2	54.3
13-May	77.0	64.0	68.7	55.0	48.0	89.6	68.9	67.5	50.9
20-May	73.0	61.4	66.3	53.2	46.0	84.7	66.3	63.3	47.1
27-May	72.0	57.1	66.2	51.8	46.0	81.2	62.8	59.1	44.2
3-Jun	72.0	57.9	65.3	51.2	44.0	80.5	63.0	59.6	44.3
10-Jun	70.0	60.7	63.3	49.5	43.0	84.7	65.9	55.5	41.1
17-Jun	67.0	57.0	62.0	48.2	43.0	74.9	62.4	53.5	39.7
24-Jun	68.0	55.5	62.0	48.6	41.0	74.2	62.6	52.3	39.1
1-Jul	68.0	56.3	61.7	47.1	41.0	65.1	60.3	48.0	35.7
8-Jul	70.0	56.2	61.4	47.1	39.0	71.4	61.3	48.3	35.4
15-Jul	66.0	54.0	60.4	45.8	39.0	65.8	60.1	46.6	34.0
22-Jul	68.0	53.3	61.8	46.1	39.0	65.8	59.4	46.9	33.3
29-Jul	72.0	56.3	61.9	46.7	39.0	73.5	68.3	47.4	33.6
5-Aug	72.0	55.7	63.0	46.4	41.0	64.4	60.7	46.0	32.7
12-Aug	70.0	54.6	62.8	46.7	41.0	65.1	61.4	45.8	31.7
19-Aug	77.0	57.2	64.1	47.3	41.0	69.3	60.4	48.2	32.8
26-Aug	76.0	61.0	64.7	47.8	43.0	74.2	65.2	49.1	33.8
2-Sep	77.0	56.1	65.3	50.3	45.0	74.2	66.2	53.7	37.9
9-Sep	79.0	56.4	66.6	49.9	45.0	71.4	63.6	52.6	35.2
16-Sep	79.0	58.7	67.0	51.3	45.0	75.6	62.4	55.4	37.6
23-Sep	79.0	60.3	68.2	52.1	45.0	75.6	65.5	57.4	39.2
30-Sep	86.0	62.3	69.2	53.5	46.0	79.8	65.5	60.5	41.0
7-Oct	89.0	63.0	70.9	55.8	49.0	85.4	67.4	65.3	44.7
14-Oct	88.0	61.8	71.0	55.7	48.0	85.4	65.5	65.0	43.9
21-Oct	86.0	63.3	70.8	56.0	50.0	86.1	68.2	66.6	44.7
28-Oct	82.0	66.0	70.8	57.7	52.0	89.6	74.2	70.0	51.1
4-Nov	93.0	66.3	72.9	59.3	52.0	91.7	68.6	74.1	53.0
11-Nov	83.0	63.3	72.8	59.6	54.0	97.3	71.7	73.3	53.7
18-Nov	88.0	64.0	73.7	60.4	52.0	98.0	73.5	77.1	56.8
25-Nov	84.0	64.0	73.4	60.7	52.0	98.7	72.5	77.2	56.3
2-Dec	91.0	64.6	75.7	62.4	55.0	100.1	70.0	81.6	59.9
9-Dec	91.0	67.8	76.6	63.6	57.0	110.6	75.0	84.2	61.3
16-Dec	90.0	65.9	77.4	64.0	57.0	109.2	74.4	86.8	62.5
23-Dec	97.0	65.4	77.6	64.6	59.0	110.6	73.5	87.4	63.2
31-Dec	88.0	67.5	77.3	65.9	59.0	116.2	75.3	90.4	69.9



	Mean Cooling Degree Days (°F)	Mean Heating Degree Days (°F)
JAN	238	3
FEB	212	3
MAR	169	10
APR	67	56
MAY	17	161
JUN	2	295
JUL	2	352
AUG	7	295
SEP	27	184
OCT	60	94
NOV	99	43
DEC	185	10
ANN	1085	1506



	Average Sensible Cooling Load	Average Sensible Heating Load	Average Latent Cooling Load	Average Latent Heating Load
	(Btu/cfm)	(Btu/cfm)	(Btu/cfm)	(Btu/cfm)
JAN	964	-292	2787	-1
FEB	773	-260	2458	-1
MAR	385	-808	1694	-3
APR	102	-2887	472	-12
MAY	13	-6241	116	-14
JUN	1	-9796	8	-95
JUL	1	-11336	0	-164
AUG	15	-9961	1	-203
SEP	81	-6851	5	-176
OCT	219	-4220	86	-61
NOV	309	-2295	438	-27
DEC	703	-807	1604	-8
ANN	3566	-55754	9669	-765

Average Annual Solar Radiation – Nearest Available Site
(Source: National Renewable Energy Laboratory, Golden CO, 1995)

No Solar Radiation
Data Available




Average Annual Solar Heat and Illumination – Nearest Available Site

(Source: National Renewable Energy Laboratory, Golden CO, 1995)

Wind Summary - December, January, and February


Labels of Percent Frequency on North Axis



Percent Calm = 16.33

Wind Summary - March, April, and May


Labels of Percent Frequency on North Axis



Percent Calm = 28.61

Wind Summary - June, July, and August


Labels of Percent Frequency on North Axis



Percent Calm = 25.01

Wind Summary - September, October, and November

Labels of Percent Frequency on North Axis



Percent Calm = 17.23