

TOCUMEN PM

Latitude = 9.05 N

Longitude = 79.37 W

Period of Record = 1973 to 1996

WMO No. 787920

Elevation = 36 feet

Average Pressure = 29.70 inches Hg

Design Criteria Data

	Design Value	Mean Coincident (Average) Values			
		Wet Bulb Temperature (°F)	Humidity Ratio (gr/lb)	Wind Speed (mph)	Prevailing Direction (NSEW)
Dry Bulb Temperature (T)	(°F)				
Median of Extreme Highs	95	78	120	9.4	NNE
0.4% Occurrence	93	78	119	10.2	NNE
1.0% Occurrence	91	77	120	9.8	NNE
2.0% Occurrence	91	77	120	9.8	NNE
Mean Daily Range	15	-	-	-	-
97.5% Occurrence	72	71	115	1.2	WNW
99.0% Occurrence	70	68	102	0.7	WNW
99.6% Occurrence	68	67	97	0.5	WNW
Median of Extreme Lows	64	63	86	0.3	WNW
	Design Value	Mean Coincident (Average) Values			
		Dry Bulb Temperature (°F)	Humidity Ratio (gr/lb)	Wind Speed (mph)	Prevailing Direction (NSEW)
Wet Bulb Temperature (T_{wb})	(°F)				
Median of Extreme Highs	85	88	172	7.5	S
0.4% Occurrence	82	88	151	6.2	S
1.0% Occurrence	81	88	146	6.1	S
2.0% Occurrence	80	87	141	6.1	S
	Design Value	Mean Coincident (Average) Values			
		Dry Bulb Temperature (°F)	Vapor Pressure (in. Hg)	Wind Speed (mph)	Prevailing Direction (NSEW)
Humidity Ratio (HR)	(gr/lb)				
Median of Extreme Highs	172	86	1.12	7.5	S
0.4% Occurrence	151	85	0.99	5.3	S
1.0% Occurrence	151	85	0.99	5.3	S
2.0% Occurrence	143	83	0.94	4.9	S
Air Conditioning/ Humid Area Criteria	# of Hours	T ≥ 93°F	T ≥ 80°F	T _{wb} ≥ 73°F	T _{wb} ≥ 67°F
		38	3592	6657	8540

Other Site Data


Weather Region	Rain Rate 100 Year Recurrence (in./hr)	Basic Wind Speed 3 sec gust @ 33 ft 50 Year Recurrence (mph)	Ventilation Cooling Load Index (Ton-hr/cfm/yr) Base 75°F-RH 60% Latent + Sensible
10	N/A	N/A	18.1 + 3.8
Ground Water Temperature (°F) 50 Foot Depth *	Frost Depth 50 Year Recurrence (in.)	Ground Snow Load 50 Year Recurrence (lb/ft ²)	Average Annual Freeze-Thaw Cycles (#)
81.8	N/A	N/A	0

*Note: Temperatures at greater depths can be estimated by adding 1.5°F per 100 feet additional depth.


TOCUMEN PM

WMO No. 787920

Average Annual Climate



Long Term Psychrometric Summary




- 50% of all observations
- 80% of all observations
- 95% of all observations
- 97.5% of all observations
- 99% of all observations

TOCUMEN PM

WMO No. 787920

Psychrometric Summary of Peak Design Values



	(°F)	MCHR	Enthalpy	1.0% Humidity Ratio	(gr/lb)	MCDB	MCWB	MC Dewpt	Enthalpy
		(gr/lb)	(btu/lb)			(°F)	(°F)	(°F)	(btu/lb)
99% Dry Bulb	70	101.8	32.7	Ratio	151.2	85.3	80.6	78.8	44.2

1.0% Dry Bulb	(°F)	MCHR	MCWB	Enthalpy
		(gr/lb)	(°F)	(btu/lb)
	91	120	77.4	40.7

WMO No. 787920

Dry-Bulb Temperature Hours For An Average Year (Sheet 1 of 5)

Period of Record = 1973 to 1996

[illegible]

Caution: This summary reflects the typical distribution of temperature in a typical year. It does not reflect the typical moisture distribution. Because wet bulb temperatures are averaged, this summary understates the annual moisture load. For accurate moisture load data, see the long-term humidity summary and the ventilation and infiltration load pages in this manual.

TOCUMEN PM

WMO No. 787920

Dry-Bulb Temperature Hours For An Average Year (Sheet 2 of 5)

Period of Record = 1973 to 1996

Temperature Range (°F)	April					May					June				
	Hour Group (LST)			Total Obs	M C W B (°F)	Hour Group (LST)			Total Obs	M C W B (°F)	Hour Group (LST)			Total Obs	M C W B (°F)
	01 To 08	09 To 16	17 To 00			01 To 08	09 To 16	17 To 00			01 To 08	09 To 16	17 To 00		
95 / 99		2	0	2	76.9		0		0	78.7		0		0	81.0
90 / 94	0	102	8	110	76.7	0	39	3	41	78.4		22	1	23	79.8
85 / 89	0	77	29	106	76.1	0	80	13	93	78.1	0	65	6	71	79.0
80 / 84	21	47	101	169	74.8	13	99	86	198	76.8	6	109	68	184	77.3
75 / 79	130	11	96	236	73.4	184	30	141	355	74.9	178	41	151	370	75.1
70 / 74	88	1	7	95	70.6	50	1	6	57	72.0	56	3	14	72	72.2
65 / 69	2		0	2	66.3	0			0	68.0					
60 / 64	0			0	62.0										

Caution: This summary reflects the typical distribution of temperature in a typical year. It does not reflect the typical moisture distribution. Because wet bulb temperatures are averaged, this summary understates the annual moisture load. For accurate moisture load data, see the long-term humidity summary and the ventilation and infiltration load pages in this manual.

WMO No. 787920

Dry-Bulb Temperature Hours For An Average Year (Sheet 3 of 5)

Period of Record = 1973 to 1996

[illegible]

Caution: This summary reflects the typical distribution of temperature in a typical year. It does not reflect the typical moisture distribution. Because wet bulb temperatures are averaged, this summary understates the annual moisture load. For accurate moisture load data, see the long-term humidity summary and the ventilation and infiltration load pages in this manual.

TOCUMEN PM

WMO No. 787920

Dry-Bulb Temperature Hours For An Average Year (Sheet 4 of 5)

Period of Record = 1973 to 1996

Temperature Range (°F)	October					November					December				
	Hour Group (LST)			Total Obs	M C W B (°F)	Hour Group (LST)			Total Obs	M C W B (°F)	Hour Group (LST)			Total Obs	M C W B (°F)
	01 To 08	09 To 16	17 To 00			01 To 08	09 To 16	17 To 00			01 To 08	09 To 16	17 To 00		
95 / 99		0		0	80.0	0			0	81.0					
90 / 94	0	7	0	7	79.2	0	16	0	16	79.1	0	33	0	33	77.7
85 / 89	0	49	1	50	78.6	0	61	4	65	78.2	0	105	10	115	76.9
80 / 84	3	133	33	169	77.1	2	116	38	156	76.9	2	85	58	145	75.8
75 / 79	120	55	187	363	74.8	114	45	172	331	74.7	75	25	142	242	73.8
70 / 74	125	4	27	156	72.0	123	2	27	151	72.0	162	1	39	201	70.9
65 / 69	0	0	0	0	68.0	1		0	1	67.0	9		0	9	66.9
60 / 64											0			0	63.3


Caution: This summary reflects the typical distribution of temperature in a typical year. It does not reflect the typical moisture distribution. Because wet bulb temperatures are averaged, this summary understates the annual moisture load. For accurate moisture load data, see the long-term humidity summary and the ventilation and infiltration load pages in this manual.

WMO No. 787920


Period of Record = 1973 to 1996

Caution: This summary reflects the typical distribution of temperature in a typical year. It does not reflect the typical moisture distribution. Because wet bulb temperatures are averaged, this summary understates the annual moisture load. For accurate moisture load data, see the long-term humidity summary and the ventilation and infiltration load pages in this manual.

Annual Summary of Temperatures



Long Term Humidity and Dry Bulb Temperature Summary




TOCUMEN PM


WMO No. 787920

Long Term Dry Bulb Temperature and Humidity Summary

Week Ending	1.0% Temp (°F)	MCWB @ 1% Temp (°F)	Mean Max Temp (°F)	Mean Min Temp (°F)	99% Temp (°F)	1.0% HR (gr/lb)	MCDB @ 1% HR (°F)	Mean Max HR (gr/lb)	Mean Min HR (gr/lb)
7-Jan	91.0	77.0	88.6	71.8	68.0	141.4	84.1	126.6	104.1
14-Jan	90.0	76.2	88.4	70.9	68.0	142.1	84.4	124.0	100.7
21-Jan	91.0	76.7	88.6	70.8	68.0	135.1	86.7	125.1	100.2
28-Jan	91.0	77.0	89.4	71.1	68.0	133.7	86.8	123.1	99.3
4-Feb	91.0	76.6	89.3	71.1	66.0	133.7	85.5	121.0	99.0
11-Feb	91.0	76.0	89.3	71.0	66.0	134.4	84.9	121.1	97.9
18-Feb	91.0	76.0	89.5	71.4	68.0	133.7	86.4	119.2	97.5
25-Feb	91.0	75.8	89.9	71.5	68.0	133.7	82.9	120.6	98.1
4-Mar	92.0	77.0	90.0	72.4	68.0	134.4	84.9	120.5	99.7
11-Mar	93.0	76.4	90.2	72.0	68.0	133.7	81.8	121.3	99.4
18-Mar	91.0	75.9	90.2	72.1	68.0	141.4	83.3	121.5	98.9
25-Mar	93.0	76.3	90.3	72.4	68.0	140.7	84.7	121.8	100.4
1-Apr	93.0	76.8	90.7	72.6	68.0	137.9	79.0	123.5	102.1
8-Apr	93.0	77.1	90.9	73.0	70.0	141.4	83.7	123.1	103.6
15-Apr	93.0	77.9	90.6	73.8	70.0	142.1	84.4	128.6	106.7
22-Apr	93.0	77.1	90.5	73.8	70.0	142.1	83.5	130.2	108.2
29-Apr	93.0	77.8	89.1	74.0	72.0	142.8	82.7	133.0	112.5
6-May	91.0	77.9	88.6	74.0	72.0	149.8	84.9	136.5	115.7
13-May	92.0	81.0	89.0	74.6	72.0	151.2	84.9	138.9	117.9
20-May	91.0	79.1	87.7	74.3	72.0	151.2	84.9	141.3	119.3
27-May	90.0	78.9	86.6	74.3	73.0	151.2	84.1	141.8	120.4
3-Jun	90.0	79.6	86.1	74.6	73.0	151.2	84.9	140.9	121.3
10-Jun	91.0	79.8	87.0	74.5	73.0	151.2	85.1	143.4	120.9
17-Jun	91.0	78.9	86.8	74.1	72.0	151.2	84.8	141.7	120.6
24-Jun	91.0	79.9	86.6	74.0	73.0	151.2	85.6	143.0	121.0
1-Jul	90.0	80.0	86.3	73.8	72.0	151.2	84.8	141.5	119.6
8-Jul	91.0	80.5	86.9	73.5	72.0	151.2	85.7	142.3	118.3
15-Jul	91.0	80.4	87.1	73.5	72.0	151.2	86.1	140.8	118.3
22-Jul	91.0	80.3	87.1	73.4	72.0	151.2	85.9	141.6	117.5
29-Jul	91.0	79.8	87.5	73.3	72.0	151.2	85.0	142.1	118.2
5-Aug	91.0	80.3	87.4	73.3	72.0	153.3	88.2	142.6	118.4
12-Aug	91.0	79.8	87.0	73.9	73.0	151.2	85.0	142.2	119.7
19-Aug	91.0	79.8	87.1	73.5	72.0	151.2	85.7	141.6	118.8
26-Aug	91.0	79.8	86.4	73.4	72.0	151.2	85.1	141.8	118.8
2-Sep	90.0	79.5	85.9	73.3	72.0	150.5	85.7	140.2	118.4
9-Sep	91.0	81.2	86.5	73.7	72.0	151.2	85.8	142.0	119.8
16-Sep	90.0	80.2	85.8	73.4	72.0	151.2	85.4	141.2	118.9
23-Sep	90.0	80.1	85.7	73.6	72.0	150.5	86.2	139.9	119.3
30-Sep	89.0	79.7	85.4	73.3	72.0	150.5	85.9	140.1	118.1
7-Oct	90.0	79.7	85.3	73.2	72.0	150.5	85.3	139.7	118.7
14-Oct	88.0	79.4	84.7	73.1	72.0	148.4	81.3	139.1	118.0
21-Oct	90.0	78.9	85.4	73.0	72.0	145.6	84.8	138.7	117.7
28-Oct	90.0	79.1	85.3	73.1	72.0	150.5	85.4	138.9	117.6
4-Nov	90.0	79.7	85.2	73.0	72.0	150.5	85.1	140.0	117.4
11-Nov	90.0	79.4	86.0	73.1	72.0	151.2	85.9	140.1	117.3
18-Nov	90.0	78.6	85.8	72.8	70.0	142.8	83.9	138.7	116.4
25-Nov	90.0	78.6	86.2	72.9	71.0	150.5	84.7	139.9	116.7
2-Dec	90.0	78.6	86.7	72.6	70.0	144.2	84.2	137.8	115.4
9-Dec	90.0	78.4	87.1	72.5	70.0	150.5	84.6	135.8	112.8
16-Dec	90.0	78.1	87.6	72.3	70.0	147.0	86.8	135.7	112.4
23-Dec	90.0	77.4	88.1	71.6	68.0	142.1	85.4	129.8	106.4
31-Dec	91.0	77.0	88.1	70.9	68.0	142.1	84.5	128.3	103.8




	Mean Cooling Degree Days (°F)	Mean Heating Degree Days (°F)
JAN	443	0
FEB	420	0
MAR	491	0
APR	493	0
MAY	469	0
JUN	432	0
JUL	434	0
AUG	434	0
SEP	401	0
OCT	385	0
NOV	399	0
DEC	419	0
ANN	5220	0



	Average Sensible Cooling Load	Average Sensible Heating Load	Average Latent Cooling Load	Average Latent Heating Load
	(Btu/cfm)	(Btu/cfm)	(Btu/cfm)	(Btu/cfm)
JAN	4148	-9	13505	0
FEB	4187	-10	11370	0
MAR	5150	-7	13158	0
APR	5230	-2	15928	0
MAY	4262	0	21321	0
JUN	3595	0	21253	0
JUL	3601	0	20975	0
AUG	3466	0	21386	0
SEP	2994	0	19946	0
OCT	2606	0	20108	0
NOV	2936	0	20496	0
DEC	3562	-3	17516	0
ANN	45737	-31	216962	0

Average Annual Solar Radiation – Nearest Available Site
(Source: National Renewable Energy Laboratory, Golden CO, 1995)

No Solar Radiation
Data Available




Average Annual Solar Heat and Illumination – Nearest Available Site

(Source: National Renewable Energy Laboratory, Golden CO, 1995)

Wind Summary - December, January, and February


Labels of Percent Frequency on North Axis



Percent Calm = 47.78

Wind Summary - March, April, and May


Labels of Percent Frequency on North Axis



Percent Calm = 46.31

Wind Summary - June, July, and August


Labels of Percent Frequency on North Axis



Percent Calm = 55.34

Wind Summary - September, October, and November

Labels of Percent Frequency on North Axis



Percent Calm = 54.09