

ZANDERY/PARAMARIBO SM

Latitude = 5.45 N

WMO No. 812250

Longitude = 55.20 W

Elevation = 49 feet

Period of Record = 1973 to 1995

Average Pressure = 29.80 inches Hg

Design Criteria Data

	Design Value	Mean Coincident (Average) Values			
		Wet Bulb Temperature (°F)	Humidity Ratio (gr/lb)	Wind Speed (mph)	Prevailing Direction (NSEW)
Dry Bulb Temperature (T)	(°F)				
Median of Extreme Highs	97	76	105	7.4	E
0.4% Occurrence	95	77	109	7.3	E
1.0% Occurrence	93	77	112	7.1	E
2.0% Occurrence	93	77	112	7.1	E
Mean Daily Range	15	-	-	-	-
97.5% Occurrence	72	72	116	0.3	E
99.0% Occurrence	70	69	105	0.1	MISSING
99.6% Occurrence	68	67	98	0.1	MISSING
Median of Extreme Lows	66	65	93	0.0	CALM
	Design Value	Mean Coincident (Average) Values			
		Dry Bulb Temperature (°F)	Humidity Ratio (gr/lb)	Wind Speed (mph)	Prevailing Direction (NSEW)
Wet Bulb Temperature (T_{wb})	(°F)				
Median of Extreme Highs	84	88	171	7.2	E
0.4% Occurrence	80	88	137	6.8	NNE
1.0% Occurrence	79	87	133	6.4	E
2.0% Occurrence	79	87	133	6.4	E
	Design Value	Mean Coincident (Average) Values			
		Dry Bulb Temperature (°F)	Vapor Pressure (in. Hg)	Wind Speed (mph)	Prevailing Direction (NSEW)
Humidity Ratio (HR)	(gr/lb)				
Median of Extreme Highs	168	88	1.12	4.9	NNE
0.4% Occurrence	143	83	0.94	4.7	N
1.0% Occurrence	141	82	0.94	4.5	NNE
2.0% Occurrence	141	82	0.94	4.5	NNE
Air Conditioning/ Humid Area Criteria	# of Hours	T ≥ 93°F	T ≥ 80°F	T _{wb} ≥ 73°F	T _{wb} ≥ 67°F
		213	3339	6759	8452

Other Site Data

Weather Region	Rain Rate 100 Year Recurrence (in./hr)	Basic Wind Speed 3 sec gust @ 33 ft 50 Year Recurrence (mph)	Ventilation Cooling Load Index (Ton-hr/cfm/yr) Base 75°F-RH 60% Latent + Sensible
10	N/A	N/A	10.5 + 3.9
Ground Water Temperature (°F) 50 Foot Depth *	Frost Depth 50 Year Recurrence (in.)	Ground Snow Load 50 Year Recurrence (lb/ft ²)	Average Annual Freeze-Thaw Cycles (#)
81.8	N/A	N/A	0


*Note: Temperatures at greater depths can be estimated by adding 1.5°F per 100 feet additional depth.

ZANDERY/PARAMARIBO

SM

WMO No. 812250

Average Annual Climate




ZANDERY/PARAMARIBO

SM


WMO No. 812250

Long Term Psychrometric Summary



- 50% of all observations
- 80% of all observations
- 95% of all observations
- 97.5% of all observations
- 99% of all observations

Psychrometric Summary of Peak Design Values



99% Dry Bulb	(°F)	MCHR (gr/lb)	Enthalpy (btu/lb)	1.0% Humidity Ratio	(gr/lb)	MCDB (°F)	MCWB (°F)	MC Dewpt (°F)	Enthalpy (btu/lb)
	70	104.6	33.1		141.4	82	78.4	77	41.8

1.0% Dry Bulb	(°F)	MCHR (gr/lb)	MCWB (°F)	Enthalpy (btu/lb)
	93	112.8	76.8	40.1

ZANDERY/PARAMARIBO SM

WMO No. 812250

Dry-Bulb Temperature Hours For An Average Year (Sheet 1 of 5)

Period of Record = 1973 to 1995

Temperature Range (°F)	January					February					March				
	Hour Group (LST)			Total Obs	M C W B (°F)	Hour Group (LST)			Total Obs	M C W B (°F)	Hour Group (LST)			Total Obs	M C W B (°F)
	01 To 08	09 To 16	17 To 00			01 To 08	09 To 16	17 To 00			01 To 08	09 To 16	17 To 00		
105 / 109															
100 / 104															
95 / 99												1	0	1	76.9
90 / 94	0	16	2	18	76.2		18	2	20	75.3		36	6	42	75.8
85 / 89	0	71	14	85	75.7	0	67	20	87	75.0	0	74	22	95	75.6
80 / 84	0	84	46	130	75.4	0	73	38	110	75.0	0	74	48	123	75.4
75 / 79	48	70	140	258	73.9	40	58	128	226	73.5	64	59	144	267	73.7
70 / 74	184	7	46	237	71.2	155	8	36	199	70.7	168	4	28	200	71.0
65 / 69	17	0	0	17	66.9	28		0	28	66.8	16	0		16	66.8
60 / 64	0	0		0	63.3	1			1	63.3	0			0	63.8

Caution: This summary reflects the typical distribution of temperature in a typical year. It does not reflect the typical moisture distribution. Because wet bulb temperatures are averaged, this summary understates the annual moisture load. For accurate moisture load data, see the long-term humidity summary and the ventilation and infiltration load pages in this manual.

ZANDERY/PARAMARIBO SM

WMO No. 812250

Dry-Bulb Temperature Hours For An Average Year (Sheet 2 of 5)

Period of Record = 1973 to 1995

Temperature Range (°F)	April					May					June				
	Hour Group (LST)			Total Obs	M C W B (°F)	Hour Group (LST)			Total Obs	M C W B (°F)	Hour Group (LST)			Total Obs	M C W B (°F)
	01 To 08	09 To 16	17 To 00			01 To 08	09 To 16	17 To 00			01 To 08	09 To 16	17 To 00		
105 / 109															
100 / 104		0		0	80.5										
95 / 99		2	0	2	76.7		0	0	0	79.0		0		0	77.5
90 / 94	0	42	5	47	76.7	0	32	3	35	77.6		32	5	37	77.4
85 / 89	0	69	21	89	76.5	0	67	14	80	77.2	0	72	9	81	77.0
80 / 84	0	78	49	127	76.2	0	92	43	135	76.8	0	81	35	116	76.7
75 / 79	122	48	151	322	74.5	163	56	180	400	74.9	121	54	178	353	74.7
70 / 74	112	1	14	127	71.3	84	1	8	93	71.9	119	1	13	133	72.2
65 / 69	6	0		6	67.0	1	0		1	67.6		0		0	
60 / 64															

Caution: This summary reflects the typical distribution of temperature in a typical year. It does not reflect the typical moisture distribution. Because wet bulb temperatures are averaged, this summary understates the annual moisture load. For accurate moisture load data, see the long-term humidity summary and the ventilation and infiltration load pages in this manual.

ZANDERY/PARAMARIBO SM

WMO No. 812250

Dry-Bulb Temperature Hours For An Average Year (Sheet 3 of 5)

Period of Record = 1973 to 1995

Temperature Range (°F)	July					August					September				
	Hour Group (LST)			Total Obs	M C W B (°F)	Hour Group (LST)			Total Obs	M C W B (°F)	Hour Group (LST)			Total Obs	M C W B (°F)
	01 To 08	09 To 16	17 To 00			01 To 08	09 To 16	17 To 00			01 To 08	09 To 16	17 To 00		
105 / 109															
100 / 104															
95 / 99		0	0	0	77.7		2	1	3	77.1		18	3	21	76.7
90 / 94	0	48	9	57	76.7	0	85	18	102	76.9	0	100	25	125	76.7
85 / 89	0	78	13	92	76.5	0	69	16	85	76.6	0	51	17	68	76.7
80 / 84	0	69	38	108	76.1	0	57	45	102	76.2	0	51	60	112	76.0
75 / 79	77	51	157	285	74.4	107	34	150	292	74.4	133	20	123	275	74.4
70 / 74	171	2	30	203	71.8	141	1	19	160	71.7	107	1	12	120	71.7
65 / 69	0	0		0	66.8	0	0	0	0	67.0					
60 / 64							0	0	0						

Caution: This summary reflects the typical distribution of temperature in a typical year. It does not reflect the typical moisture distribution. Because wet bulb temperatures are averaged, this summary understates the annual moisture load. For accurate moisture load data, see the long-term humidity summary and the ventilation and infiltration load pages in this manual.

ZANDERY/PARAMARIBO SM

WMO No. 812250

Dry-Bulb Temperature Hours For An Average Year (Sheet 4 of 5)

Period of Record = 1973 to 1995

Temperature Range (°F)	October					November					December				
	Hour Group (LST)			Total Obs	M C W B (°F)	Hour Group (LST)			Total Obs	M C W B (°F)	Hour Group (LST)			Total Obs	M C W B (°F)
	01 To 08	09 To 16	17 To 00			01 To 08	09 To 16	17 To 00			01 To 08	09 To 16	17 To 00		
105 / 109		0	0	0	81.0										
100 / 104		0	0	0	80.0										
95 / 99		18	3	21	76.6		6	1	7	76.8		0		0	77.0
90 / 94	0	103	24	127	76.9	0	84	15	99	76.9		30	3	33	77.0
85 / 89	0	51	18	69	76.8	0	60	16	76	76.9	0	73	14	86	76.6
80 / 84	0	57	60	116	76.1	0	62	51	113	76.4	0	77	40	118	76.2
75 / 79	141	19	136	295	74.5	134	29	148	311	74.6	71	65	159	295	74.4
70 / 74	107	1	8	116	71.7	106	0	9	115	71.9	168	3	32	203	71.7
65 / 69			0	0							10	0		10	66.9
60 / 64															

Caution: This summary reflects the typical distribution of temperature in a typical year. It does not reflect the typical moisture distribution. Because wet bulb temperatures are averaged, this summary understates the annual moisture load. For accurate moisture load data, see the long-term humidity summary and the ventilation and infiltration load pages in this manual.

SM

WMO No. 812250


Dry-Bulb Temperature Hours For An Average Year (Sheet 5 of 5)

Period of Record = 1973 to 1995


[illegible]

Caution: This summary reflects the typical distribution of temperature in a typical year. It does not reflect the typical moisture distribution. Because wet bulb temperatures are averaged, this summary understates the annual moisture load. For accurate moisture load data, see the long-term humidity summary and the ventilation and infiltration load pages in this manual.

Annual Summary of Temperatures




Long Term Humidity and Dry Bulb Temperature Summary




ZANDERY/PARAMARIBO SM**WMO No. 812250****Long Term Dry Bulb Temperature and Humidity Summary**

Week Ending	1.0% Temp (°F)	MCWB @ 1% Temp (°F)	Mean Max Temp (°F)	Mean Min Temp (°F)	99% Temp (°F)	1.0% HR (gr/lb)	MCDB @ 1% HR (°F)	Mean Max HR (gr/lb)	Mean Min HR (gr/lb)
7-Jan	90.0	76.5	86.1	72.6	68.0	141.4	81.8	128.9	111.2
14-Jan	90.0	75.8	85.2	72.2	68.0	136.5	80.4	128.2	110.4
21-Jan	90.0	76.0	85.9	72.0	68.0	141.4	83.0	127.7	108.1
28-Jan	90.0	76.1	86.2	71.7	68.0	137.9	82.5	126.5	108.9
4-Feb	90.0	75.6	86.3	71.6	67.0	139.3	82.0	125.5	106.5
11-Feb	90.0	75.2	86.5	71.4	68.0	136.5	82.1	124.3	105.1
18-Feb	90.0	75.2	86.4	71.1	67.0	141.4	80.7	123.9	103.0
25-Feb	90.0	75.2	86.1	72.0	68.0	135.8	80.6	124.4	106.6
4-Mar	90.0	75.1	86.9	72.3	68.0	141.4	81.6	125.9	107.2
11-Mar	91.0	75.0	87.3	71.9	67.0	140.7	83.1	124.4	105.2
18-Mar	91.0	75.5	87.5	72.3	68.0	140.0	80.0	125.9	108.0
25-Mar	93.0	76.5	87.5	72.6	70.0	141.4	82.7	127.9	108.1
1-Apr	93.0	76.4	87.3	72.6	70.0	141.4	82.4	128.1	108.9
8-Apr	93.0	76.4	87.9	73.0	68.0	141.4	82.3	130.5	111.3
15-Apr	93.0	76.9	88.0	73.2	70.0	141.4	82.7	130.5	111.5
22-Apr	93.0	75.7	87.9	73.7	70.0	142.1	82.2	132.6	112.8
29-Apr	91.0	76.9	87.3	73.8	71.0	142.8	81.9	133.6	115.9
6-May	92.0	75.1	88.0	73.9	71.0	142.1	81.3	133.9	113.9
13-May	91.0	77.6	87.8	73.9	72.0	149.1	82.3	136.0	116.0
20-May	91.0	78.3	87.4	73.8	72.0	142.8	83.7	137.3	117.3
27-May	91.0	77.5	86.6	74.0	72.0	144.9	81.9	136.0	117.2
3-Jun	92.0	76.2	86.5	74.1	72.0	142.1	80.9	134.8	117.4
10-Jun	91.0	77.3	87.5	73.7	73.0	141.4	81.6	135.2	117.0
17-Jun	91.0	77.7	87.4	73.4	72.0	141.4	81.1	135.3	116.4
24-Jun	91.0	76.9	87.6	73.4	72.0	141.4	81.8	133.7	114.6
1-Jul	91.0	76.7	88.2	73.2	72.0	141.4	81.4	132.8	113.8
8-Jul	91.0	76.6	88.0	73.0	72.0	141.4	81.8	132.2	112.7
15-Jul	92.0	77.4	88.5	73.1	72.0	140.7	81.3	130.7	111.7
22-Jul	92.0	76.6	88.1	73.0	71.0	140.7	83.2	130.2	111.1
29-Jul	92.0	76.6	89.1	73.2	72.0	141.4	82.4	131.7	110.6
5-Aug	93.0	77.1	89.3	73.2	71.0	141.4	82.0	130.4	110.4
12-Aug	93.0	76.8	89.9	73.3	72.0	141.4	81.7	131.0	109.9
19-Aug	93.0	77.0	90.0	73.7	72.0	141.4	82.2	132.1	111.0
26-Aug	94.0	77.0	90.9	73.9	72.0	141.4	82.8	131.8	109.0
2-Sep	94.0	76.9	90.5	73.8	72.0	141.4	83.1	131.9	109.2
9-Sep	95.0	77.1	91.0	73.8	72.0	141.4	83.0	132.2	109.9
16-Sep	95.0	76.8	91.1	73.7	72.0	141.4	84.1	129.8	107.7
23-Sep	95.0	76.6	92.2	74.0	72.0	141.4	82.7	130.9	108.5
30-Sep	95.0	76.9	92.3	73.8	72.0	141.4	84.1	131.5	109.3
7-Oct	95.0	76.5	92.1	73.9	72.0	141.4	82.7	132.1	109.2
14-Oct	97.0	76.4	92.2	73.6	72.0	141.4	82.4	132.3	108.6
21-Oct	95.0	77.0	92.1	74.0	72.0	141.4	82.3	130.2	108.9
28-Oct	95.0	76.9	91.5	73.7	72.0	142.1	82.4	132.1	110.4
4-Nov	95.0	77.1	91.6	74.2	72.0	142.1	83.3	132.1	110.0
11-Nov	95.0	76.1	90.7	74.2	72.0	142.1	82.5	132.6	111.7
18-Nov	94.0	76.7	90.5	73.8	72.0	141.4	82.4	132.3	111.6
25-Nov	93.0	76.8	89.3	74.0	72.0	141.4	82.5	132.9	114.4
2-Dec	93.0	76.7	88.2	73.7	72.0	142.1	81.5	133.5	114.9
9-Dec	91.0	76.6	87.6	73.3	70.0	141.4	82.6	132.9	115.8
16-Dec	91.0	76.9	86.9	73.2	70.0	141.4	81.6	132.2	115.1
23-Dec	91.0	76.7	86.5	72.7	68.0	141.4	81.8	131.7	113.3
31-Dec	90.0	76.7	86.6	72.3	68.0	141.4	81.6	129.7	110.9



	Mean Cooling Degree Days (°F)	Mean Heating Degree Days (°F)
JAN	354	0
FEB	339	0
MAR	397	0
APR	397	0
MAY	429	0
JUN	402	0
JUL	432	0
AUG	445	0
SEP	463	0
OCT	475	0
NOV	461	0
DEC	395	0
ANN	4990	0


Average Ventilation and Infiltration Loads
(Outside Air vs. 75°F, 60% RH summer; 68°F, 30% RH winter)



	Average Sensible Cooling Load	Average Sensible Heating Load	Average Latent Cooling Load	Average Latent Heating Load
	(Btu/cfm)	(Btu/cfm)	(Btu/cfm)	(Btu/cfm)
JAN	2680	-4	8964	0
FEB	2635	-8	7943	0
MAR	3563	-4	10134	0
APR	3730	-1	11213	0
MAY	3711	0	13120	0
JUN	3433	0	12451	0
JUL	3971	0	11044	0
AUG	4525	-1	10253	-2
SEP	5153	0	9870	0
OCT	5261	0	10713	0
NOV	4783	0	10372	0
DEC	3325	-2	9960	0
ANN	46770	-20	126037	-2

Average Annual Solar Radiation – Nearest Available Site
(Source: National Renewable Energy Laboratory, Golden CO, 1995)

No Solar Radiation
Data Available





Average Annual Solar Heat and Illumination – Nearest Available Site

(Source: National Renewable Energy Laboratory, Golden CO, 1995)

Wind Summary - December, January, and February



Labels of Percent Frequency on North Axis



Percent Calm = 50.65

Wind Summary - March, April, and May


Labels of Percent Frequency on North Axis



Percent Calm = 49.00

Wind Summary - June, July, and August


Labels of Percent Frequency on North Axis



Percent Calm = 53.79

Wind Summary - September, October, and November

Labels of Percent Frequency on North Axis



Percent Calm = 45.88